



---

# RBSANCHEZ PME CONSULTANTS & ASSOCIATES, INC.

---

PROVEN, RELIABLE AND COST-EFFECTIVE SOLUTIONS



Unit 3603, 36F Makati Executive Tower II, Buendia Ave. cor. Dela Rosa St.  
Brgy. Pio Del Pilar, Makati City Philippines 1230



(02) 8776-5879 / 8638-2604



(+63) 927-300-6000 Globe / 947-507-000 Smart



info@rbs-engineers.com  
rosensanchez@yahoo.com



[www.rbs-engineers.com](http://www.rbs-engineers.com)







# PRINCIPAL ENGINEER

## ENGR. ROSENDO B. SANCHEZ

PME, ASEAN, ACPE, ASHRAE



**HVAC ENGINEER** of the “**WORLD’S TALLEST BUILDING**” **THE BURJ KHALIFA TOWER** Dubai, UAE. Served as “**HVAC DESIGN MANAGER**” and “**HVAC ENGINEER ON RECORD**”. Year 2006-2007.



**MECHANICAL ENGINEERING BOARD TOPNOTCHER (1<sup>st</sup> PLACE)** with the Highest Score Achievement in the government Licensure Examinations for Mechanical Engineers in 1981, with **CUMLAUDE** honors graduate in the **University of the Philippines, Diliman**.



**PSME “TOME AWARDS”** as “**THE MOST OUTSTANDING MECHANICAL ENGINEER**” in Research and Innovations Consultancy by National P.S.M.E. (**Philippine Society of Mechanical Engineers**) and by the **Professional Regulation Commission** at SMX PSME Convention Center of Year 2018.





## SOCRATES NOMINATION COMMITTEE

2 Woodin's Way, Oxford, OX1 1HF · United Kingdom

[www.awards.ebaoxford.co.uk](http://www.awards.ebaoxford.co.uk)

+441865794362



The nomination and award to



INTERNATIONAL PROJECT


# MANAGER OF THE YEAR

for professional achievements in  
commercial activities



# ENGR. ROSENDO B. SANCHEZ

## PME, ASEAN, ACPE

-  Awarded for 'Manager of the Year' 2020 for contributing to International Engineering Design Projects for the Burj Khalifah Dubai "WORLD'S TALLEST BUILDING"

As the "HVAC DESIGN MANAGER" and "HVAC ENGINEER ON RECORD". Engr. Rosen Sanchez is the official signatory of all building's HVAC construction drawings of Years 2006-2007.





- Featured by the **PHILIPPINE DAILY INQUIRER**, issue September 21, 2008 Metro Global Section A18 – half page as the **Filipino HVAC Design Manager and engineer to watch**.



# PHILIPPINE NEWS

## ENGR. ROSENDO B. SANCHEZ

### PME, ASEAN, ACPE

- FEATURED IN A **DUBAI NEWSPAPER** AS HVAC DESIGN MANAGER for the LANDMARK DUBAI Project.
- NEWS EMARATALYOUNG**: Issued last September 29, 2006 page 38 as the selected “HVAC Design Manager” to watch in the Dubai Burj Khalifah Project.







# AWARDS AND RECOGNITION

## ENGR. ROSENDO B. SANCHEZ PME, ASEAN, ACPE



 **TOME AWARDEE “THE MOST OUTSTANDING MECHANICAL ENGINEER”** in Consultancy by National P.S.M.E. (Philippine Society of Mechanical Engineers) and by the Professional Regulation Commission at SMX PSME Convention Center of Year 2011.

 **“THE BEST MECHANICAL ENGINEERING DESIGN AND CONSULTANCY SERVICES”** by the **ASIA PACIFIC EXCELLENCE AWARDS COUNCIL (APAC)**, Awarded December 15, 2018.





# OUR SERVICES

“COMPREHENSIVE EXPERTISE” FOR YOUR DESIGN

**NEEDS!** Engineering Sciences and Services from Design of Industrial Plants, High-end Hotels and Residences, Testing and Commissioning, Trouble-shooting to Plant Maintenance and retrofit Services with specialization in:

- **HVAC Design & Consultancy Services** for I.T. Server Farms, Semiconductor Fab Cleanrooms, Logistics Warehouses and systems, Bio-Chem facilities, Food and Medical Services, Oil & Gas, Chemical and Process Plants, Chiller Systems, Water and Waste Water Distribution networks, Mining, Power Plants, Malls, Medical, Commercial & BPOs, Real Estate Development, etc.
- **Plant Operation & Maintenance (O&M) and Instrumentation and Controls Upgrade.** running your plant efficiently and reliably **ONSHORE/OFFSHORE** on a 24/7/365 basis and design of Controls and Instrumentation and upgrades
- **Improving Reliability and Energy Efficiency**, Reliability-Centered-Maintenance RCM-II and Asset Operations and Asset Integrity Improvements.
- **Testing and Measurements and Analysis**, Troubleshooting and Test and Commissioning works in the commercial, industrial, and both onshore and offshore industrial Oil & Gas, Mining and Semi-Conductor, Server and Solar Farms, etc, testing on HVAC, air & gases, weather & environment, water and viscous and Bingham fluids.
- **Computational Fluid Dynamics (CFD), Simulations**, Numerical Modelling, and complex Mathematical techniques to predict conditions using supercomputers for the ff fluids: Weather and Climate Change, Wind and Water, Viscous fluids, Sludge and Non-Newtonian and Mining fluids, Environmental Gases and Pollutants and Soot and Waste Sludge pumping and Wastewater treatment. Newtonian, Bingham and Heterogenous and slurry fluid flows.



# RBS PHILOSOPHY on WORK/LIFE

Trust in the Sciences/Truth and on Filipino Engineers and Countrymen



- REALISTIC AND WORKABLE PROJECT CONTEXT/LOCALIZED SOLUTIONS
- ECONOMICAL & OPTIMIZED ENERGY / ENVIRONMENTAL APPROACH
- LONG-TERM AND MUTUALLY-BENEFICIAL SOLUTIONS/RELATIONSHIPS
- HONEST AUTHENTIC COMMUNICATION: NON-JUDGMENTAL AND CONFIDENTIAL
- HAS A CODE OF ETHICS AND WITH MUTUAL RESPECT
- TEAMWORK & DEDICATION: A VISION FOR PHILIPPINE INDUSTRIALIZATION
- ETERNAL MISSION & STRUGGLE: HOW TO “SEEK THE TRUTH FROM FACTS”




[illegible][illegible]



# ENGINEERING/SCIENCES CONSULTANCY for SHELL MALAMPAYA OFFSHORE PUMPING PROJECT

📍 Offshore, Northwest of Palawan, Phillippines, August 2024 and ongoing

- RBS supplies the Scientific Structural and Mathematical Modelling and Mechanical Vibration problem-solving expertise for the 1.2MW vertical pump.
- The Pump system is an advanced offshore pump-up siphoning., pump body only weighs approx 40 tons , 1.200 MW and pump body height of 60-meters.





# YCO CLOUD CENTER Data Center (Philippines)

📍 Light Industry and Science Park IV, Batangas  
July 2023 ongoing 2024.



Gensler



## ■ **US\$500M DATA CENTER to rise in Batangas** (2023 News Bulletin today)

**12-MW YCO CLOUD DATA CENTER is certified to TIA 942 Rated III and ISO 22237**

The design team is headed by U.S. based Gensler Architects and Manila-based JSLA Architects.

RBS is the Mechanical CFD consultant.



■ RBS is responsible for the HVAC CFD Design Consultancy and Airflow/Ventilation Consultancy for DATA CENTER HALLS, SERVER RACKS and CABINETS, HVAC units, i.e. Precision CRAH/PAHU equipment Cooling Airflows and the external cooling of the high-power density 2.5MW multiple DIESEL GENERATORS as well as cooling of the mission-critical battery/UPS power supplies.



# Western Digital Storage Technologies (Philippines) Corp.

📍 HGST Plant. 109 Technology Ave SEPZ, Laguna Technopark Sta Rosa, Laguna, from February Years 2022-2024.

- **DESIGN and CONSULTANCY SERVICES for 70,000 sqm WD PLANT EXPANSION to capacity of 150mu with CLEANROOMS designed to ISO CLASS 100.**



RBS will design the ARCHITECTURAL, STRUCTURAL, CIVIL, ELECTRICAL, MECHANICAL, ELECTRONIC, I.T. & DATA INFRASTRUCTURE of the WD PLANT.



- **WD has contracted RBS as a “single-point responsibility” for the engineering design of the plant’s new 3000sqm CLEANROOM to ISO CLASS 100 levels.**




# BPO LEED 4.0 COMPLIANT HIGH RISE DESIGN AND CONSULTANCY OF ARANETA CYBERPARK TOWER 3

📍 Araneta Center, Cubao, Manila | Years 2023 to ongoing 2024



- HVAC System Design and Consultancy for Mechanical Systems of Araneta Cyberpark Tower 3 of 33 floors (90,000 sqm) high rise building. Araneta Cyberpark Tower 3 is a LEED 4.0 Compliant Design.
- RBSanchez PME is the Mechanical Systems Design Consultant






# CONSULTANCY SERVICES FOR PLDT DATA CENTER 20MW POWER PLANT

📍 PLDT DATA CENTER, Nicanor Garcia, Makati, Metro Manila



■ RBS SUPERCOMPUTERS POWERS THE CFD STUDIES AND CONSULTANCY SERVICES FOR THE 20MW DIESEL POWER FOR SERVER FARMS PLDT IN MAKATI CITY. October 2022 to 2023



## 2.4 Thermophysical and Energy Models

Thermophysical models are used to describe cases where the thermal energy, compressibility, and/or mass transfer is important. OpenFOAM allows thermophysical properties to be constant, or functions of temperature, pressure and composition. Thermal energy can be described either in form of enthalpy or internal energy [3, 6]. Detailed explanations of this models are presented in the guide available online.

Transport equations for specific kinetic energy  $k = v_i^2/2$  can be obtained by multiplying the momentum equation to the  $v_i$ :

$$v_i \rho \frac{Dv_i}{Dt} = v_i \rho \frac{\partial v_i}{\partial t} + v_i \rho \frac{\partial(v_j v_i)}{\partial x_j} = -v_i \frac{\partial p}{\partial x_i} + v_i \frac{\tau_{ij}}{\partial x_j} + v_i \rho f_i \quad (11)$$

Note that the left hand side of Equation 11 can be equated to

$$v_i \rho \frac{Dv_i}{Dt} = \frac{\rho}{2} \frac{D(v_i v_i)}{Dt} = \rho \frac{Dk}{Dt} \quad (12)$$

and, thus allowing to rewrite the transport equation for the specific kinetic energy and internal energy into:

$$\rho \frac{Du}{Dt} = -p \frac{\partial v_i}{\partial x_i} + \tau_{ij} \frac{\partial v_i}{\partial x_j} + v_i \rho f_i \quad (13)$$

$$\rho \frac{Dk}{Dt} = -p \frac{\partial v_i}{\partial x_i} + \tau_{ij} \frac{\partial v_i}{\partial x_j} - \frac{\partial q''_i}{\partial x_i} + q''' \quad (14)$$

where  $q''$  is conductive heat flux and  $q'''$  is the volumetric heat source. Adding Equations 13 and 14, the total energy transport equation dictated by  $e = k + u$  is formed as:

$$\rho \frac{De}{Dt} = \rho \frac{D(k+u)}{Dt} = \frac{\partial(v_i \sigma_{ij})}{\partial x_j} - \frac{\partial q''_i}{\partial x_i} + q''' + v_i \rho f_i \quad (15)$$




# SCIENTIFIC CONSULTANCY and MINING OPERATIONS SERVICES FOR THE PHILS. LARGEST OFFSHORE MINING PROJECT



📍 Offshore in Cagayan, Philippines, July 2021 and ongoing 2023.

■ RBS supplies the Scientific. Geological Mining, Structural and Mathematical Modelling and Mechanical Engineering expertise and the Operations and Maintenance Services for Offshore Platform Sand Extraction and On board Mineral Processing Plant of JDVC Corp.

■ The operation requires a capesize siphon vessel with a width of 32 meters on average and a length of about 300 meters. Complete with three (3) full sets of magnetic separators, ejector system for deep-sea pump-up siphoning from down to 200 meters after the sea bed, washer apparatus, drying apparatus, and loading facilities for mineral transfer to export vessels.





# HIGH RISE BUILDING HVAC DESIGN AND CONSULTANCY WYNDHAM RESORT HOTEL TOWER

📍 Quezon City | 2018 to 2019



- HVAC System Design and Consultancy for Mechanical Systems of a 22-storey, 100-meter high tower with 800TR of chilled water systems.

- Using the latest technology of SMART Chillers with multiple TurboCore compressors for energy savings.

The First Wyndham Garden Hotel in the Philippines





# CONSULTANCY SERVICES FOR CFD OF CARPARK OF MOA PARKSUITES TOWER



📍 Aseana Business Park, MOA, Mall of Asia, Metro Manila | Sept 2020

- RBS is the CFD (Computerized Fluid Dynamics) and PME Consultant for Carpark Ventilation for **Monarch Parksuites**. It is an 17-storey composed of four towers that stands on a lot **area** of 18,000+ **square meters**. It is Multi use luxury building (Sepr 2020)



Figure 10 describes the filtered streamlines seeded in the genset patch boundary. The streamlines shows the air patterns from different sources. It can also be seen that indistinguishable amount air were drawn out from the basement level. In this result, it is empirical to have a fresh air injection system on the basement to compensate the drawn air.




Figure 10. Streamlined flow with arrow lines seeded from the generator patch at  $t = 900$  seconds





# RBS CONSULTANCY FOR THE OFFSHORE MINING MAGNETIC SURVEY PROJECT.



📍 Offshore in Cagayan, Phillippines, Sept 12 2022

■ RBS supplies the holistic scientific and mathematical analysis and consultancy for the Sand Extractions using the Magnetic survey specialist Dr. Bernie B. Barcelona. He is Phd Doctor of Science at Tokyo University of Science.

■ GEOPHYSICAL EQUIPMENT USED. Magnetic Transponders. PASI Resistivity Meter, RM-1 Model (3x) SEISMIC REFRACTION/MASW - GEOMETRIX-24 CHANNELSSCHMIDT HAMMER FOR ROCKS AND CONCRETE THERMAL RESISTIVITY INSTRUMENT (THERMTEST) TERRAMETER TERRALOC PRO GPRs – GSSI




**B. Barcelona**  
**Geological Surveying**  
**Services**  
*...because we understand the Earth and its processes*





📍 Las Pinas Maynilad, Paranaque City, Metro Manila 2023





# MANILA WATER INC. DESIGN AND CFD CONSULTANCY PROJECT EAST BAY R.O. WATER TREATMENT PLANT

📍 Laguna Lake Reverse Osmosis Plant, Phillippines  
Laguna Lake, August 2022

■ RBS supplies consultancy for the CFD Engineering and environmental marine expertise for the diffusion and dispersal of inflows and outflows from the Plant.

■ **MANILA EAST BAY WATER TREATMENT Reverse-Osmosis PLANT** Tedagua with Philippine construction company First Balfour secured a contract in December 2020 for the design and construction of the East Bay Drinking Water Treatment Plant.




Figure 14. Comparison of brine dispersion at terminal heights reached by jet angles 15° and 30°

From the equation above, the extrapolated values coefficient for the  $Z/\Delta F_{0.2}$  of angles 15° and 30° yields to 0.1924215 and 0.6170892, respectively. From these values, the resulting approximation terminal height  $Z$ , on both angles were 0.997 meters and 1.6520 meters that closely matches the results obtained from the fluid simulation presented in figure 14.

#### Summary

The results of the far-field dilution values at 30° were similar to case 1 with insignificant density difference at same sample points. The major difference of the two cases were the terminal height. The terminal height or peak height reached by the plume were 1.7 meters compared to the 1.1 meters at case 1. It was observed as well that the impact dilution distance and near-field dilution were shorter than of case 1, implying that case 3 has lesser chance of re-circulation. But in the context of varying lake depths, the water level at the Laguna lake ranges from +2 meters minimum, +3.6 meters average and +5.1 meters maximum levels all in reference from the lake bed. With these depth values, +1.7 meters terminal height at 30° jet angle is still possible but with a high risk of lower dilution and faster transport due to surface current caused by stratified density depth layers and basically the free-surface waves and wind. At the case where the lake water level is at or below the minimum, high risk of re-circulation, stratification and progressive brine transport is likely to occur if the angle of jet is at 30°. Thus, it can be other angles such as 20° can be studied if the terminal height is acceptable with associated lower risk compared to this current case.

#### 5.4 Case 4 - 30° jet inclination and underwater current

Similar to the approach done in case 2 and 3 to determine the significant changes, if there are, when the angles was changed to 30°. As observed from figure 17, the difference in the far-field dilution area was similar to that of case 2. It is presented in closer look in figure 18 that the diffusion shape is similar and the diffusion levels are also similar. The difference seems insignificant when compared in the far-field but can be observed to have minor differences in the concentration values in the near-field. Nonetheless, the difference were still insignificant aside from plume characteristics (thinner and longer) at 30° as seen in the plan view.

**LAGUNA LAKE PROJECT.** The contract is for the design and construction of a Drinking Water Treatment Plant (DWTP) sludge with a production capacity of 50,000m<sup>3</sup> per day in the Pakil Lake area, Laguna Lake, east of Manila.



# CONSULTANCY SERVICES FOR NEW CHILLER SYSTEM CAPEX OF THE PHILIP MORRIS PLANT IN BATANGAS

📍 Bulacan | June 2023



- RBS design and consultancy services for NEW CAPEX CHILLERS AND UPGRADE OF CHILLER PIPING SYSTEMS FOR ENERGY SAVINGS.



- RBS optimizing the existing chilled water distribution, chiller piping and pumps loads as well as the “**Sequence of Operations**” of Siemens controls and instrumentation of the plant.



# CONSULTANCY SERVICES FOR COMPRESSED AIR SYSTEM CDA OF THE PHILIP MORRIS PLANT IN BATANGAS

📍 Sto Tomas, Batangas | August 2022

- RBS design and consultancy services for CDA Air compressor systems for **EFFICIENCY** and **ELECTRICAL SAVINGS**



- RBS to optimized the existing CDA system and cooling tower system as well as the “**Sequence of Operations**” of the PLC controls and instrumentation of the plant.



# ENERGY SAVINGS CONSULTANCY for CHILLED WATER OF THE MARIKINA PLANT PRODUCTION AREA 1 & 2

📍 Brgy. Fortune Marikina City| May to July 2021



RBS delivered **MERALCO ELECTRICAL SAVINGS** savings of 109kw.

- This saved **PHP2M MERALCO** electricity charges annually only by **controls adjustments** (without any upgrade of equipment or other expenses).

RBSANCHEZ PME CONSULTANTS & ASSOCIATES, INC

SAVINGS REALIZED AFTER MULTIPLE CALCULATIONS

CHILLER – CONDENSER PUMP – COOLING TOWER

CURRENT PLANT OPERATIONAL CONDITION					OPTIMIZED PLANT OPERATIONAL CONDITION					
	1	2	3	kW reading	DIFF	1	2	3	kW reading	
COOLING TOWER	60 Hz	-	60 Hz	59.50 kW	42.00 kW	30 Hz	30 Hz	30 Hz	17.50 kW	
CONDENSER PUMP	60 Hz	-	-	64.90 kW	23.20 kW	45 Hz	-	-	41.70 kW	
CHILLED WATER PUMP	38.59 Hz	-	-	-	-	38.65 Hz	-	-	-	
CHILLER	-	-	88.30% Part-load condition	127.90 kW	44.00 kW	-	-	56.63% Part-load condition	83.9 kW	
TOTAL KW READING				252.30 kW	109.20 kW	TOTAL KW READING				143.1 kW

109.20 kW x Php 6.00 per kW-hr x 10 hr = **Php 6,552.00 per day OR Php 196,560.00 per month**



RBS optimized the existing **“Sequence of Operations”** of controls and instrumentation of the plant.



# WHOLE CHILLER PLANT EFFICIENCY ASSESSMENT KW/TON AND STUDY for HITACHI SEMI-CONDUCTOR PLANT

📍 HGST Plant. 109 Technology Ave SEPZ, Laguna Technoparkm. August 2021 to current.

- **RBS supplies DESIGN AND CONSULTANCY SERVICES** for the Kw/ton evaluation, capex upgrade and remodelling for the existing HGST plant.



- **HGST has requested and RBS agreed to have a “single-point responsibility”.**

**RBS will be responsible for the complete design of ARCHITECTURAL, STRUCTURAL, CIVIL WORKS. ELECTRICAL, MECHANICAL I.T. & DATA INFRASTRUCTURE & ALL OTHER TRADES REQUIRED FOR THE PLANT.**



# DESIGN AND CONSULTANCY OF MECHANICAL SYSTEM FOR STEEL ASIA MANUFACTURING PLANT

📍 Plaridel, Bulacan

- RBSanchez Inc is the design engineer and consultant for the Steel Manufacturing Plant Year 2016 to 2017





# DESIGN AND CONSULTANCY FOR WHOLE HVAC SYSTEM OF ROBINSONS MALL SAN PEDRO



ROBINSONS LAND  
CORPORATION

YOUR DREAMS, OUR FOUNDATION.

📍 179 Manila S Road, San Pedro, Laguna | 2021



- RBSanchez Inc. is the HVAC Design Consultant for the 104,500 sqm mall building of Robinson's San Pedro Mall, Laguna.





# WHOLE CHILLER PLANT EFFICIENCY ASSESSMENT KW/TON AND STUDY for HITACHI SEMI-CONDUCTOR PLANT



📍 HGST Plant. 109 Technology Ave SEPZ, Laguna Technopark. August 2021 to current.

- RBS supplies DESIGN AND CONSULTANCY SERVICES for the Kw/ton evaluation, capex upgrade and remodelling for the existing HGST plant.



STRUCTURAL, CIVIL, MECHANICAL, ELECTRICAL, MECHANICAL I.T. & DATA INFRASTRUCTURE & ALL OTHER TRADES REQUIRED FOR THE PLANT.



# DESIGN AND CFD CONSULTANCY FOR ENVIRONMENTAL PROJECT EAST BAY WATER TREATMENT PLANT



📍 Laguna Lake Reverse Osmosis Plant, Philippines  
Laguna Lake, August 2021



**First  
Balfour**

■ **RBS supplies consultancy for the CFD Engineering and environmental marine expertise** for the diffusion and dispersal of inflows and outflows from the Plant.

■ **MANILA EAST BAY WATER TREATMENT RO PLANT** (REVERSE OSMOSIS plant) Tedagua with Philippine construction company First Balfour secured a contract in December 2020 for the design and construction of the East Bay Drinking Water Treatment Plant.




Figure 14. Comparison of brine dispersion at terminal heights reached by jet angles 15° and 30°

From the equation above, the extrapolated values coefficient for the  $Z/\delta F_z$  of angles 15° and 30° yields to 0.1324215 and 0.617082, respectively. From these values, the resulting approximation terminal height  $Z$ , on both angles were 0.997 meters and 1.4520 meters that closely matches the results obtained from the fluid simulation presented in figure 14.

#### Summary

The results of the far-field dilution values at 30° were similar to case 1 with insignificant density difference at same sample points. The major difference of the two cases were the terminal height. The terminal height or peak height reached by the plume were 1.7 meters compared to the 1.1 meters at case 1. It was observed as well that the impact dilution distance and near-field dilution were shorter than of case 1, implying that case 3 has lesser chance of re-circulation. But in the context of varying lake depths, the water level at the Laguna lake ranges from +2 meters minimum, +3.6 meters average and +5.1 meters maximum levels all in reference from the lake bed. With these depth values, +1.7 meters terminal height at 30° jet angle is still possible but with a high risk of lower dilution and faster transport due to surface current caused by stratified density depth layers and basically the free-surface waves and wind. At the case where the lake water level is at or below the minimum, high risk of re-circulation, stratification and progressive brine transport is likely to occur if the angle of jet is at 30°. Thus, it can be other angles such as 20° can be studied if the terminal height is acceptable with associated lower risk compared to this current case.

#### 5.4 Case 4 - 30° jet inclination and underwater current

Similar to the approach done in case 2 and 3 to determine the significant changes, if there are, when the angles was changed to 30°. As observed from figure 17, the difference in the far field dilution area was similar to that of case 2. It is presented in closer look in figure 18 that the diffusion shape is similar and the diffusion levels are also similar. The difference seems insignificant when compared in the far-field but can be observed to have minor differences in the concentration values in the near-field. Nonetheless, the difference were still insignificant aside from plume characteristics (thinner and longer) at 30° as seen in the plan view.

**LAGUNA LAKE PROJECT.** The contract is for the design and construction of a Drinking Water Treatment Plant (DWTP) sludge with a production capacity of 50,000m<sup>3</sup> per day in the Pakil Lake area, Laguna Lake, east of Manila.



# DESIGN OF VISCOUS PUMPING SYSTEMS OF LA CARLOTA SUGAR REFINERY



📍 La Carlota Sugar Refinery, Negros Occidental | August 2020

- Tanks, Piping and pump system design using CFD simulation to predict and model the design of the VISCOUS FLUIDS behavior for molasses and magma pumping systems.



- RBSanchez Inc. is a long-term Partner with Global Horizons Inc. in various industrial projects.





# BRINE CHILLER TEST AND MEASURE OPERATIONAL STUDY for THE HITACHI SEMI-CONDUCTOR PLANT


📍 HITACHI Plant. Laguna Technopark. August 2021

- RBS supplies DESIGN AND CONSULTANCY SERVICES for the re-design and remodelling of BRINE CHILLER piping works. August 2021 and ongoing.

**HITACHI**  
Inspire the Next

The Future of  
Digital Payments

**HITACHI**





# CONSULTANCY SERVICES FOR CLASS 100 to CLASS 10,000 MEDICAL DEVICES CLEANROOMS

📍 ARTHRO LOGIC, INC. Plant, Brgy. Fortune , Marikina City, MM, June 2021

- RBS is the HVAC PME Engineering Consultancy Services for the design of new Cleanrooms, and Controls system designer for the Plant.

Project starts June 1, 2021.

- ARTHRO LOGIC, INC. Plant will manufacture medical orthopedic devices and implants under Class 100 and 10k cleanroom conditions.



Typical TKA System VS. Logic 1.0 TKA System



Less components.  
Less instruments.  
Less surgical time.  
Less inventory.  
Less cost.



# CONSULTANCY SERVICES FOR CHILLED WATER ENERGY AND COOLING OF THE MARIKINA PLANT PRODUCTION AREA 1 &

📍 Brgy. Fortune Marikina City| May to June 2021



RBS delivered **MERALCO ELECTRICAL SAVINGS** savings of 109kw.

- This saved **PHP2M MERALCO** electricity charges annually without any upgrade of equipment or expenses.



RBSANCHEZ PME CONSULTANTS & ASSOCIATES, INC

SAVINGS REALIZED AFTER MULTIPLE CALCULATIONS

CHILLER – CONDENSER PUMP – COOLING TOWER

CURRENT PLANT OPERATIONAL CONDITION					OPTIMIZED PLANT OPERATIONAL CONDITION					
	1	2	3	kW reading	DIFF	1	2	3	kW reading	
COOLING TOWER	60 Hz	-	60 Hz	59.50 kW	42.00 kW	30 Hz	30 Hz	30 Hz	17.50 kW	
CONDENSER PUMP	60 Hz	-	-	64.90 kW	23.20 kW	45 Hz	-	-	41.70 kW	
CHILLED WATER PUMP	38.59 Hz	-	-	-	-	38.65 Hz	-	-	-	
CHILLER	-	-	88.30% Part-load condition	127.90 kW	44.00 kW	-	-	56.63% Part-load condition	83.9 kW	
TOTAL KW READING				252.30 kW	109.20 kW	TOTAL KW READING				143.1 kW

109.20 kW x Php 6.00 per kW-hr x 10 hr = **Php 6,552.00 per day OR Php 196,560.00 per month**

- RBS optimized the existing “**Sequence of Operations**” of controls and instrumentation of the plant.

Project done from Jan to April, 2021.







## CONSULTANCY SERVICES FOR BALARA WATER TREATMENT PLANT 1




Figure 8. Sludge bed development after t hours




Figure 10. Sludge concentration along basin depth at different sections,  $t = 24$  hours

## OPTIMAL AND COST-EFFECTIVE SLOPE AND SUMP PIT INTERVALS

Using measurements and results of the CFD model, the recommendation is to have a basin bed slope of 1:300 at sump pit intervals every 60 meters. These figures were realized after series of parametric studies and cost effective solutions analysis.



### Analysis of Gravity Induced Sludge Collection and Removal for Sedimentation Basin 1 and 2 of Balara Treatment Plant 1

RBSanchez PME Consultants and Associates Inc.<sup>1</sup>

<sup>1</sup>RBSanchez Engineering Department, Makati Executive Tower 2, Makati, Manila  
Website: [www.rbs-engineers.com](http://www.rbs-engineers.com)

#### Executive Summary

Proposed sludge removal method for two continuous sedimentation basins were investigated prior to retrofitting. The initial system includes three sump pumps in pits at 60-m interval along the 180-m basin. The floor were sloped at 1:300 for gravity induced sludge transport.

CFD simulations were conducted to determine the behavior of pertinent parameters such as flow field, sludge detention, basin dimensions, sludge zone depth and rheological properties both for the accumulation period and during sludge removal operation. OpenFOAM solver driftFluxFoam was employed to perform the calculation for mass and momentum conservation for two-phase flow as a mixture. Applying the mixture model, water was set as the continuous phase and the settle-able sludge as dispersed phase. Furthermore, the sludge was modeled as a non-Newtonian fluid with rheological properties similar to bingham plastic. Measurements and validation tests were conducted to verify numerical solver predictions. Caution was exercised in using available data on best effort basis to represent actual site conditions.

The following items are summarized as the findings and corresponding recommendation, as proposed:

1. Gravity-induced transport of sludge by floor slope of 1:300 is insufficient. The initial design for sludge collection and removal will not be effective for long term operation. In this slope, the transport is very minimal that the sludge were accumulated in the interval span even after sludge pump operations. **Recommendation:** Increasing the slope to 1:150 to improve sludge transport without significant effect to the sedimentation process. Although, steeper slopes were observed to greatly improve the transport than 1:150 and shown in the concentration curves. Partial velocity disturbance and minor eddy formation may occur in the basin floor that may cause partial re-suspension in the floor depth.
2. Shortened distance between sump pits will improve the sludge collection and removal. Aside from increasing the slope, another parametric study findings in decreasing the interval was observed. It was observed that shortening the intervals significantly increases the collection rate overall as the area of removal is proportionally increased. However, further decreasing the interval may incur higher operational cost and maintenance cost as the sludge pumps would require regular maintenance due to its purpose. **Recommendation:** In-depth cost analysis are not included in this tender. Considering operational and maintenance cost, it is still recommended to reduce the interval up to 45-meter interval from the 60-interval. It is necessary to test run sludge operation to set optimum interval for each section of the basin so that issues previously discussed are avoided.
3. The study were set to consider an initial inlet of 300 NTU turbidity condition, as provided to be one of the highest in record. The study considered also a 100 NTU computational domain, however yields to insignificant findings difference compared to the 300 NTU domain, thus is not pursued further.
4. Adjust the floor slope of the sump pit section towards the pump base accordingly, to allow sludge movement in the sump pit to be drawn towards the pump and ensure sludge transport from the sides of the pit.
5. Selected pump specification (capacity and TDH) suffices as the sludge pump is operated intermittently to draw sludge out of the basin. In addition, verify the pump's capability at fluid viscosity.

Continuous Sedimentation CFD  
Analysis (RBS)

REF: 15-2018-RBS-CH-SEC-BAS-  
CFD-005A

Written by  
RBS Data Team


© 2020, Owned and produced  
by RBSanchez PME Consultants  
and Associates Inc.



# CHILLER PLANT EFFICIENCY ASSESSMENT @ HGST SEMI-CONDUCTOR WAFER PLANT

📍 HGST Plant. 109 Technology Ave SEPZ, Laguna Technoparkm. August 2021 to November 2021

- **RBS supplies HVAC CONSULTANCY SERVICES** for the assessment, evaluation, and operational chiller upgrades and CFD fluid modelling and design of chillers, pumps, cooling towers and piping works for the HGST plant.






# ASSESSMENT AND AUDIT CONSULTANCY FOR CHEVRON MSSC HVAC



📍 RCBC Plaza, Makati, Manila | July 2019-Feb 2020

- **HVAC HEAT MAPPING, CFD Analysis and Consultancy for the Improvement for Chevron BPO Offices, a 10,000 sqm, total of 12 floors in RCBC Building, Ayala, Makati CBD.**

- **System consultancy for Cooling load Improvement, airflows of AHUs, fans, ducting, ACH, cooling and ensure proper room conditions.**





# MECHANICAL DESIGN CONSULTANCY SERVICES FOR MANILA WATER



📍 Balara Water Treatment Plant 1 and 2. Quezon City, Manila | Jan 2020

## Analysis of Gravity Induced Sludge Collection and Removal by Suction Pumps for Sedimentation Basin 1 and 2 of Balara Treatment Plant 1

RBSanchez PME Consultants and Associates Inc.<sup>1</sup>

<sup>1</sup>Drex Dela Torre, Mechanical Engr. RBSANCHEZ PME Consultants and Associates Inc., 36th Flr. Makati Executive Tower 2 Cor. Dela Rosa St. Makati. Website: [www.rbs-engineers.com](http://www.rbs-engineers.com)

<sup>2</sup>Engineering Department

### Executive Summary

The proposed sludge removal method on the two continuous sedimentation basin are investigated prior to their retrofit. The system includes 3 sump pits each with a transfer pump and placed at every 60 meters along the basin. The bottom floor is sloped towards the sump pit at a 1:300 gradient for gravity induced transport of sludge.

CFD simulations were conducted to determine the behavior of pertinent parameters such as flow field, sludge detention, dimensions of the tank, sludge zone depth and rheological properties both for the accumulation period and during sludge removal operation. OpenFoam solver driftFluxFoam was employed to perform the calculation for mass and momentum conservation for two-phase flow as a mixture. Applying the mixture model, water was set as the continuous phase and the settle-able sludge as dispersed phase. Furthermore, the sludge was modelled as a non-Newtonian fluid with rheological properties similar to bingham plastics.

Measurements and validation tests were conducted to verify numerical solver predictions. Caution was exercised in using available data on best effort basis to represent actual site conditions.

The findings of the study are summarized in the following:

1. The initial design for sludge collection and removal will not be effective for long term operation.
  - (a) Gravity-induced transport of sludge to the sump by floor slope of 1:300 is insufficient.
2. Steeper slopes and shortened distance to sump pit and will improve sludge collection and removal.
  - (a) Increasing floor slope to 1:50 and 1:30 will improve sludge transport significantly.
  - (b) Decreasing the sump pit interval will proportionally increase area of effect of suction pumps leading to better collection.
3. Selected pump capacity suffices as the sludge pump is operated intermittently to draw sludge out of the basin
4. Numerical solver well estimates settling time in validation experiments and predicts sludge concentration curves at different points in the basin.

From these findings, the corresponding recommendations are herein proposed:

1. Retain frequency of collection points (sump pits) at every 60 meters.
2. Increase basin floor slope to 1:50 for effective sludge transport towards the sump pit.
3. Adjust floor at sump pit section to approach sump pit base to ensure sludge transport from the sides of the sump pit.
4. Select pump capacity considering sludge viscosity ranging from  $XY$  mPa-s.
5. It is necessary to test run sludge operation to set optimum interval for each section of the basin so that issues previously discussed are avoided.





# CFD CONSULTANCY FOR MANILA WATER @ BALARA WATER TREATMENT PLANT 1 AND 2



📍 Balara Treatment Plant (BTP) Sedimentation Basin 1 and


- 2 facilities. ~~Over Fluid Dynamics~~ <sup>Completed Fluid Dynamics</sup> 2019-2020 simulation to predict the sedimentation through the basins and sludge accumulation. CFD results to be used as a basis for design for continuous sludge pumping system.





# HVAC DESIGN AND CONSULTANCY OF ALLEGRO MICROSYSTEMS PHILS INC.

Sampaguita, Marimar Village, Parañaque





# AVON PLANT DESIGN OF CLEANROOMS



## **AVON PHIL. CORP**

Analysis of Chilled Water and  
HVAC Plant with RBS as  
Consultant 2006

HVAC system design consultant



# CONSULTANCY SERVICES FOR CHILLERS OF THE BATANGAS PLANT

📍 First Philippine Industrial Park Batangas, Sto Tomas | January 2021 to April 2021



- RBS is the HVAC PME Engineering Consultancy Services for the Optimization, Trouble-shooting and retrofit for the Chilled water system, Air Side AHUs and Cleanrooms, and Controls system designer for the Plant.

Project starts Dec 1, 2020.





# CFD AND DESIGN CONSULTANCY SERVICES FOR DESIGN OF GLAS TOWER PROJECT



📍 Ruby St, Ortigas Commercial Center | Aug 2020


- RBS is the HVAC System Design Engineer and PME CFD Consultant. For the first double-glazed, triple Low-E glass tower in Ortigas @ 188-meter with are of 102,000 square meters with 9MW gensets.

Multi use building for BPOs, Offices and Hotel. (Year 2020)





## Asian Hospital, Alabang, Muntinlupa City, Metro Manila





# CONSULTANCY SERVICES AND PUMP PERFORMANCE ASSESSMENT AND RE DESIGN OF TWELVE (12) METRO MANILA PUMP STATIONS




📍 Maynilad Pump Stations in Metro Manila and Cavite | December 2018 to October 2019



- RBSanchez Inc. is the Mechanical Consultant for the Maynilad Water System Assessments, measurements and analysis for 120 pumping units in various pumping stations for a total of 120 large water pumps under the GHD contract.



RBSanchez Inc. was also tasked by GHD to select and manage electrical consultant as subcontractor.





# DESIGN OF 200TR “PAINT BOOTHS” HVAC FOR MAU “ONCE THROUGH” AND “CHILLERS IN SERIES”

📍 Toyota Special Economic Zone, Sta. Rosa, Laguna



- RBS Design of Plant HVAC with Xtreme Engineering for “Once Through” and “Chillers-in-Series and MAU/AHUs design for 100% Fresh air supply for the Paint Spray Booths car painting works.
- RBS is the HVAC system design consultant.





## OTHER SERVICES DONE FOR MAYNILAD :

**ULTRASONIC PIPE THICKNESS MONITORING, VIBRATION ANALYSIS, LIGHTING ASSESSMENT, RELIABILITY CENTERED MAINTENANCE RCM 2 ASSESSMENT FOR LONG TERM ASSET MANAGEMENT SERVICES.**

📍 Maynilad Pump Stations in Manila and Cavite | 2019





# CONSULTANCY SERVICES AND PUMP PERFORMANCE ASSESSMENT OF 120 PUMPS IN MAYNILAD PUMPING STATIONS

📍 Maynilad Pump Stations in Metro Manila and Cavite | 2019




Synthesis Report				
Filter: Equipment name (+) \ Tree order (+)				
Location	Equipment	Diagnosis		Recommendations
		Previous Date	Current Date	
PAGCOR\	BOOSTER PUMP #1		FAIR	Realign Motor and Pump Shaft
			15/11/2018 10:55:42	
		Oper.	Oper. DfCnd	
PAGCOR\	BOOSTER PUMP #2		FAIR	Purge Pump Bearings with fresh greases
			15/11/2018 10:52:36	
		Oper.	Oper. DfCnd	
PAGCOR\	BOOSTER PUMP #3		FAIR	Realign Motor & Pump Shaft, Monitor Cavi
			15/11/2018 10:49:19	
		Oper.	Oper. DfCnd	
PAGCOR\	BOOSTER PUMP #4		GOOD	Continue monitor vibrations periodically
			15/11/2018 10:46:08	
		Oper.	Oper. DfCnd	
PAGCOR\	BOOSTER PUMP #5		FAIR	Monitor the evolution
			15/11/2018 10:40:18	
		Oper.	Oper. DfCnd	
PAGCOR\	BOOSTER PUMP #6		FAIR	Monitor Slight cavitations
			15/11/2018 10:36:28	
		Oper.	Oper. DfCnd	
PAGCOR\	STORAGE PUMP #1		FAIR	Realign Motor and Pump Shaft
			15/11/2018 11:02:24	
		Oper.	Oper. DfCnd	
PAGCOR\	STORAGE PUMP #2		FAIR	Monitor the evolution
			15/11/2018 10:59:20	
		Oper.	Oper. DfCnd	





Quezon Ave, Diliman, Quezon City, M. Manila | 2019 to present

Quezon Ave, Diliman, Quezon City, M. Manila | 2019 to present





# DESIGN AND OPERATIONS SERVICES

## FABRICATION PLANT FAB 1 SEMICONDUCTOR

- Supply of HVAC Design Consultancy and Chiller Operations Services in Cleanroom environments

📍 Laguna Technopark, Biñan, Laguna

SUNPOWER®

RBS has own personnel deployed on-site from Years 2007-2014 on a non-stop on a 24/7/365 basis.







# CONSULTANCY SERVICES FOR THE CHILLER PLANT SYSTEM HVAC ENERGY OPTIMIZATION

 FPIP, Sto.Tomas , Batangas



- The HVAC optimization and control system design results to drop in energy consumption and optimization of operations of the plant as shown.
- The optimization also recommended the removal of the primary pumps of chiller plant leading to drop in energy consumption.






# ENVIRONMENTAL AND MAINTENANCE ASSESSMENT OF MAYNILAD PUMP STATIONS IN METRO MANILA



📍 Maynilad Pump Stations in Manila and Cavite | 2019





# MODCO DESIGN AND OPERATIONS CLEANROOM SERVICES

## SUNPOWER®

📍 East Main Ave, Laguna Technopark Sta. Rosa, Laguna

- **MODCO MODULE SEMICON SunPower Corporation**  
Supply of HVAC Consultancy and Trane Chiller  
Operations Services for MODCO Module Manufacturing  
Plant

RBS has own personnel deployed on-site from Years  
2007-2016 on a non-stop on a 24/7/365 basis.





# ILIGAN LANAOS SHELL TERMINAL ETHANOL AND BLENDING FACILITY



📍 Iligan, Lanao del Norte

- Mechanical Design and Consultancy of the Iligan Depot Ethanol and Blending Facilities.





# CONSULTANCY SERVICES OF THE FIRE-TUBE BOILER REINSTALLATION



📍 PMFTC Plant C&D, Marikina, Manila | Sept 2019

- Consultancy services and management of various teams and discipline for the boiler transfer from Batangas Factory to Marikina Factory. The project management includes the decommissioning phases, system passivation, packaging, hauling and transport, installation, testing and commissioning works in conformance to local standards and codes.






# DESIGN AND CONSULTANCY FOR THE HVAC OF BULACAN HATCHERY BREEDER FARM



📍 Math Breeder Farm Inc., Bustos, Bulacan | 2019

- Design and consultancy services for a cleanroom HVAC. Math Breeder Farm is biological area serving setters and hatchers of chicken and egg.
- RBSanchez Inc. is the HVAC system design consultant of the Math Breeder Farm.





# DESIGN, CONSULTANCY AND ANALYSIS OF HGA-15 CLEANROOM HVAC SYSTEM FOR HITACHI GLOBAL TECHNOLOGIES

📍 HGST, Laguna Technopark, Biñan, Laguna | September 2014



- HVAC Analysis and Consultancy for System retrofit for Class 10,000 cleanroom to balance airflows among three (3) air handling units, resizing of fans, ducting, ACH, cooling and ensure proper room pressurization for the 1,150 sqm cleanroom space.
- RBSanchez Inc is the Mechanical Systems Design Consultant of HGST Philippines.






# REDESIGN OF PROBLEMATIC MAU AND AHU SYSTEM OF CLEANROOMS HGA-14 FOR HITACHI GLOBAL TECHNOLOGIES

📍 HGST, Laguna Technopark, Biñan, Laguna | December 2012



- Psychrometric design and specifications of coil for Make-up Air units, ducting and fan systems to enable accurate relative humidity control without the use of reheat. Ensure even cleanroom room temperature, uniform movement, and balance cooling.

- RBSanchez Inc is the Mechanical Systems Design Consultant of HGST Philippines.





# KRAFT FOODS HVAC DESIGN OF PHASED COOLING OF FOOD GRADE CHEESE COOLING TUNNEL PRODUCTION LINE



## **CLASS 10K CLEANROOMS OF KRAFT FOOD CORP**

RBS Design of New Chilled Water Plant and  
COOLING TUNNEL DESIGN with Trane Phils. Inc. with  
Air cooled 230 ton TRANE chillers

2007 HVAC system design






# SHELL SWIFT PROJECT VESSELS

## DESIGN OF INSTRUMENTATION, PUMPS & PIPING FOR FUEL OIL BLENDING FACILITIES FOR PANDACAN TERMINALS

📍 Pandacan, Metro Manila

- A Shell Marine Swift project, of pump and piping design project for the fuel oil blending of four (4) vessel designs of Floating Fuel Oil Blending Facilities for transfer of Pandacan Terminals is a design project of RBS Engineering (now RBSanchez Inc).





# DESIGN AND CONSULTANCY OF LITHIUM-BROMIDE STEAM ABSORPTION INDUSTRIAL CHILLER SYSTEM

Bagumbayan, Libis, Quezon City, Metro Manila



- Design and Installation of green energy lithium-bromide steam absorption chiller for the Oleochemical Processing Plant's HVAC system.



**Lithium-Bromide STEAM ABSORPTION  
CHILLER & HVAC SYSTEM (800 TONS)  
OLEO-FATS INC.**



# HVAC AND CHILLER PLANT ENERGY OPTIMIZATION FOR THE MANILA COATS TEXTILE PLANT

📍 Marikina City, Marikina Metro Manila



- The HVAC optimization yields to a savings of Php 480k per month of MERALCO bills (See letter from Coats Manila Bay Inc.). RBSanchez Inc. is the Mechanical Design Consultant for Manila Coats.



Coats Manila Bay, Inc.  
Lopez Jaena Street  
Tanong, Marikina City 1804  
Philippines  
Tel. No.: (632) 941-9590 to 99  
General Fax: (632) 941-3677

12th January 2006

MR. RENE LAFIGUERA  
Facilities Manager  
MANILA BAY SPINNING MILLS INC.  
COATS MANILA BAY INC.

SUBJECT: PROJECT REFERENCE PERMISSION

*"RBS Engineering Technologies (through the consultancy services of Engr Rosen Sanchez) was able to save our company a total of 120,000 kilowatt-hours of energy (Savings approx @Pesos 4.00 /kw-hr = PHP480,000.00 / month ) for every month of operation".*

*"We are pleased with their in-depth analysis and low-cost yet effective solutions they have recommended in improving our plant's energy efficiency."*

I hereby give my consent for RBS Engineering Technologies or its assignees to use my comments quoted above for the purpose of reference. I understand that I will receive no payment or compensation for this permission.

*[Signature]*  
MR. RENE LAFIGUERA  
Facilities Manager  
MANILA BAY SPINNING MILLS INC.  
Lopez Jaena St, Bo. Tanong, Marikina City  
Metro Manila, Philippines (Tel Nos. 941-9590 to 99)



# CONSULTANCY SERVICES FOR THE DESIGN OF TOBACCO DRYER and LEAF DRYING FACILITIES

📍 PMFTC Cagayan De Oro, Misamis Oriental | June to August 2019



- RBSanchez Inc. is the Dryer Leaf HVAC Design Consultant.

The dryer must perform and adapt to the product specs and ambient conditions at all times of the year, to minimize the losses due to over and under/over drying of tobacco leaves through different phases and air conditions.





# CONSULTANCY SERVICES FOR DISCUSSIONS WITH NINE (9) PHILIP MORRIS PLANTS WORLDWIDE



📍 PMFTC Plant C&D, Marikina, Manila | Year 2019

- RBS services includes the Training and Discussion groups on Energy Savings schemes for HVAC Chillers Systems, Boilers and Compressed Air for Plant operation, Maintenance and Energy Efficiency Optimization.

Held in PMFTC Marikina Plant with thirty (30) Philip Morris Plant Engrs (Local and Foreign) in attendance.

Affiliate	Location
Pakistan (Sahiwal)	Sahiwal
Russia (Izhora)	St. Petersburg
Russia (Kuban)	Krasnodar
Kazakhstan (Almaty)	Almaty Oblast
Ukraine (Kharkiv)	Kharkiv
Turkey (PHILSA)	Izmir
Indonesia (Sukorejo)	Sukorejo
Indonesia (Karawang)	Karawang
Korea (Sanmak)	Yangsan-si, Gyeongsangnam



# DESIGN AND CONSULTANCY OF NEW FOOD GRADE 10K CLEANROOMS FOR NESTLE WYETH



📍 Canlubang Factory, Cabuyao, Laguna

- Psychrometric design and specifications of coil for Make-up Air units, CLEANROOM Class 10000, food grade for AHU and coil selection and equipment, ducting and fan systems to enable accurate relative humidity control without the use of reheat. Ensure even cleanroom room temperature, uniform movement, ACH and balance cooling.
- Nestle Wyeth Canlubang Plant is a food-grade milk canning and dryer cleanrooms with AHU and fresh air system design.





# DESIGN AND CONSULTANCY OF NEW HVAC CHILLER PLANT SYSTEM and MEDICAL 10K CLEANROOMS

📍 Laguna Technopark, Biñan, Laguna



- Design and Installation of new chiller system including the piping and pumping system, air handling units, and fan coil units for cleanrooms as well as the control systems for the Terumo Plant.






# SHELL TABANGAO OIL REFINERY DESIGN OF SHELL LABORATORY HVAC AND AIR AND EXHAUST SYSTEM

📍 Tabangao Refinery, Batangas



- An HVAC and Exhaust Design system for toxic fumes ventilation system at Pilipinas Shell Petroleum Oil Refinery.





# DESIGN AND CONSULTANCY FOR THE HVAC CLEANROOMS AND FIRE PROTECTION OF NEW PEPSICO SNACK PLANT



📍 PEPSI Snack Plant Cabuyao, Laguna

- RBSanchez Inc. is the HVAC Design Consultant and Fire protection system design engineer for the New PEPSICO Pepsi Snack Plant Clean rooms food grade for a total of 15,000 sqm.





# DESIGN AND CONSULTANCY OF HVAC SYSTEM FOR INDUSTRIAL TEXTILE PLANT WITH EVAPORATIVE COOLING WASHERS



📍 FTI Complex, Taguig, Taguig

- HVAC Design and consultancy services for PENN Philippines Textile plant with Evaporative Washers and 430-TR Trane Chillers.






# CFD DESIGN AND CONSULTANCY

“GREEN” NATURAL VENTILATION

## TAGAYTAY HIGHLANDS BADMINTON COURT

📍 Tagaytay City | 2006

- RBSanchez Inc. is the HVAC Design Consultant for the CFD NATURAL VENTILATION DESIGN OF THE SIX (6) INDOOR BADMINTON COURTS





# DESIGN AND CONSULTANCY OF NEW AIR-COOLED CHILLED WATER PLANT FOR CLEANROOMS

📍 Corinthian Plaza, Legazpi Village, Makati, Metro Manila



- Design and consultancy services for the new 120-TR air cooled chilled water plant with new AHU and ducting system for the Rolex Corinthian Plaza.






# CONSULTANCY SERVICES FOR THE SHELL AGUSAN TERMINAL NEW PUMPING FACILITIES

📍 Cabadbaran, Agusan, Mindanao



- Mechanical Design and Consultancy of the new **SHELL PUMPING FACILITIES**, The design of Shell Ethanol and Blending Storage Facilities in Cabadbaran, Agusan, Mindanao





# CONSULTANCY SERVICES FOR NEW SHELL CAGAYAN DE ORO PUMPING FACILITIES

📍 Cagayan de Oro



- Mechanical Design and Consultancy of the new **SHELL PUMPING FACILITIES**, The design of Shell Ethanol and Blending Storage Facilities in Cagayan de Oro Shell Depots



Pilipinas Shell Petroleum Corporation		July 14, 2010
Client: Metalite Builders Development Company, Inc.		
Proposal No: RC10-06-23 01		
Item No: ITEM 001E		
Attn: Mr. Albert Dumalaog		
		i-FRAME™
MODEL:3196 STI SIZE:1x1.5-8 QTY: 2		
Operating conditions		
SERVICE	E100	
LIQUID	Ethanol Temp. 85.0 deg F, Vapor Pres. 1.62 psi abs, SP GR 0.780, Viscosity 4.200 cp, rated / max. suction pressure 0.0 / 0.0 psi g	
CAPACITY Rated	63.4 gpm	<i>Metalite to review Hydraulic calculation reference agreed 70 psi (min) on base fuel pressure.</i>
HEAD	288.0 (ft)	
Performance at	3500 RPM	
PUBLISHED EFFY	42.5% (CDS)	
RATED EFFY	40.5% with contract seal	
RATED POWER	8.9 hp (incl. Mech. seal drag 0.3%). (Run out 14.4 hp)	
NPSHR	3.4 ft	
DISCH PRESSURE(R)	97.4 psi g (99.3 psi g @ Shut off) based on 0.0 psi g rated suction pressure	
PERF. CURVE	5008-2 (Rotation CW viewed from coupling end)	
SHUT OFF HEAD	294.2 ft	
MIN. FLOW	Continuous Stable: 19.7 gpm Hydraulic: 19.7 gpm Thermal: N/A	
Materials		
CONSTRUCTION	Carbon Steel with 316SS impeller	
CASING	Carbon Steel (max.casing pressure @ rated temperature 250.0 psi g)	
ST.BOX COVER	Carbon Steel	
IMPELLER	316SS - Open (7.8750 in rated, max=8.0000 in, min=5.0000 in)	




# DESIGN AND CONSULTANCY OF A CLEANROOM HVAC SYSTEM FOR HITACHI GLOBAL TECHNOLOGIES

📍 HGST, Laguna Technopark, Biñan, Laguna | May 2014



- Complete HVAC System design for a CLASS 1000 1,200 sqm cleanroom with a 750 kVA equipment load to ensure moisture balance and uniform cooling and room pressures, and controllable relative humidity without the use of 65 kW Reheat.
- RBSanchez Inc is the Mechanical Systems Design Consultant of HGST Philippines.





# DESIGN AND CONSULTANCY OF THE NEW FILINVEST FESTIVAL SUPERMALL EXPANSION

📍 Fil-Invest Festival Mall, Alabang, Muntinlupa



**AECOM**

- The Fil-Invest Festival Supermall is a 12.5 hectares air conditioned area and the first mall in the Philippines with a low energy-friction drop chilled water piping system, using reverse-return piping technique of a 5,350-TON dual-compressor chiller plant design.
- RBSanchez Inc was subcontracted by AECOM Inc to serve as its HVAC System Design Consultant for the Year 2012 to 2016.






# DESIGN AND CONSULTANCY FOR CHEVRON MSSC OFFICES HVAC SYSTEM – PHASE 2

📍 RCBC Plaza, Makati, Manila | September 2019 to February 2020



■ **System HVAC  
Design and  
Consultancy  
services**

■ **RBS was also tasked  
to handle Testing  
And Commissioning  
Services**



DRAWING IN PROGRESS - NOT TO BE USED FOR CONSTRUCTION



# BPO COMMERCIAL BUILDING HVAC DESIGN AND CONSULTANCY OF THE MERIDIAN PLAZA



📍 Double Dragon Plaza, Pasay City, Manila

- RBSanchez Inc is the HVAC system design engineer and consultant for the 278,131 sqm for a total of 11 floors of the Double Dragon Plaza located at Edsa Extension corner D. Macapagal Avenue in Pasay City near the Mall of Asia.






# DESIGN AND CONSULTANCY FOR DESIGN OF THE NEW CHILLED WATER PLANT

📍 San Jose del Monte City, Bulacan

- Design and Consultancy services for the Upgrade of HVAC DX System to a new Chilled Water Plant for the 50,000 sqm commercial mall.
- RBSanchez Inc. is doing the complete design and consultancy services for the Manuela Properties.






# DESIGN AND CONSULTANCY OF WHOLE PLANT HVAC CHILLED WATER SYSTEM OPTIMIZATION

📍 HGST, Laguna Technopark, Biñan, Laguna | 2018



- Chilled water equipment system redesign of existing main chilled water pipeline supply and return, sub-branches & main chilled water pipeline in Phase 1-5.
  - RBSanchez Inc is the Mechanical Systems Design Consultant of HGST Philippines Year 2020.





# DESIGN AND CONSULTANCY FOR WHOLE HVAC SYSTEM OF STARMALL PRIMA TAGUIG



📍 Levi Mariano Ave., Taguig, Metro Manila | June 2017

- RBSanchez Inc. is the HVAC Design Consultant for the Starmall Prima Taguig located at L. Mariano Ave. Taguig beside Camella Greenville and Pacific Residences.





# CONSULTANCY SERVICES FOR HVAC

- **ASCOTT HOTEL AND GLORIETTA 4 HVAC SYSTEM**  
HVAC Consultancy and Chiller Operations/Maintenance.  
RBS has technical personnel deployed on-site on a 24/7/365 basis.
- Years 2007-2018





# BPO HIGH RISE BUILDING HVAC DESIGN AND CONSULTANCY OF A ARANETA CYBERPARK TOWER 2

📍 Araneta Center, Cubao | Years 2016 to 2017

- HVAC Design Engineer and Consultancy for Mechanical Plant Systems of Araneta Cyberpark Tower 2 of a total of 86,689 sqm high rise building.





# DESIGN AND CONSULTANCY FOR WHOLE HVAC SYSTEM OF ROBINSONS MALL ORMOC

📍 Carigara, Ormoc City, Leyte | 2016

- RBSanchez Inc. is the HVAC Design Consultant for the 35,80 sqm mall building at Ormoc, Leyte.



ROBINSONS LAND  
CORPORATION

YOUR DREAMS, OUR FOUNDATION.





# DESIGN AND CONSULTANCY FOR WHOLE HVAC SYSTEM OF NCCC MALL BUHANGIN

📍 Buhangin District, Davao City, Davao del Sur | 2016



- RBSanchez Inc. is the HVAC Design Consultant for the 26,704 sqm commercial mall building, New City Commercial Corp. located at Davao City, Davao del Sur.





# DESIGN AND CONSULTANCY FOR WHOLE HVAC SYSTEM OF ROBINSONS TACLOBAN TERMINAL



📍 Tabuan, Marasbaras, Tacloban City, Leyte | 2017

- RBSanchez Inc. is the HVAC System Design engineer and consultant for the whole air-conditioning system of Robinson's Place Tacloban Terminal in Tabuan, Tacloban in Leyte.





# HVAC DESIGN AND CONSULTANCY OF ALASKA HEAD OFFICES

RBS Design of New Chilled Water  
Plant and Cooling System of ALL  
Offices

2007 HVAC system design





# DESIGN AND CONSULTANCY OF MEP FOR ST. LUKES HOSPITAL AT THE FORT

📍 5<sup>th</sup> Avenue, Global City, Taguig, Metro Manila | 2008

- MEP Design and Consultancy Services of St. Luke's Medical Center Global City and RBS was subcontracted by Meinhardt Philippines Inc. for the designs analysis.



**St. Luke's**  
Medical Center  
Quezon City · Global City



**MEINHARDT**  
PHILIPPINES, INC.



MDC-FB ST. LUKE'S MEDICAL CENTER PROJECT  
Joint Venture FORT BONIFADO TAGUIG CITY  
**SAFETY BULLETIN BOARD**  
PROJECT STARTED: JANUARY 2007  
PROJECT COMPLETION: JULY 2009  
THIS PROJECT HAS ALREADY ACCUMULATED  
A TOTAL MANHOURS OF 7,628  
PREVIOUS MANHOURS: 9,328  
PROJECT TO DATE 1,649,8



# TESTING AND COMMISSIONING OF CHILLED WATER SYSTEM AND AIR SIDE SYSTEM FOR ST. LUKES HOSPITAL AT THE FORT

📍 5th Avenue, Global City, Taguig, Metro Manila | 2008



**St. Luke's**  
Medical Center  
Quezon City · Global City



- HVAC Test and Commissioning Services and Consultancy to TRANE Philippines Inc for Chillers and Medical AHU systems






# CHEVRON Inc. CONSULTANCY PHASE 1

**HVAC HEAT MAPPING,  
Analysis and Consultancy for the  
Improvement for Chevron BPO  
Offices, a 10,000 sqm, total of 12  
floors in RCBC Building, Ayala,  
Makati CBD.**

**System consultancy for Cooling  
load Improvement, airflows of  
AHUs, fans, ducting, ACH,  
cooling and ensure proper  
conditions.**

**2018 December**



**RBSanchez PME Consultants & Associates, Inc.**



# DESIGN AND CONSULTANCY FOR AIR-CONDITIONING SYSTEM OF NATIONAL GRID CORP OFFICES

📍 Quezon Ave. Diliman, Quezon City | 2015



- HVAC system design engineer and consultant for 1,400 sqm building using psychrometric design and specifications of coil for make-up air units, ducting and fan systems.





# HVAC CONSULTANCY, OPERATIONS & MAINTENANCE SERVICES

- **WELLS FARGO LLC** Wells Fargo Drive, McKinley Hill, Upper McKinley Road, Taguig City, Metro Manila

**WELLS  
FARGO**



RBS has personnel deployed on-site from Years 2017-2020 on a 24/7/365 basis.





# MAINTENANCE SERVICES



## ■ GLAXO SMITH KLINE

Chino Roces Avenue, **Pasong Tamo** Ext. Makati City



RBS has own personnel deployed on-site from Years 2007-2019 on a non-stop on a 24/7/365 basis.





# ENERGY SAVINGS AND MAINTENANCE SERVICES



## ■ ROBINSONS MALLS MAGNOLIA

Aurora Boulevard, Q.C.

Supply of HVAC Consultancy and Trane  
Chillers Operators Maintenance Services from  
Year 2013-2019





# DESIGN AND CONSULTANCY FOR CHILLED WATER SYSTEM AND PIPING FOR CHEESE CLASS 1K CLEANROOMS

📍 Sucat, Parañaque City



- Design and consultancy for the cooling tunnel process for Class 1000 cleanrooms FOOD GRADE in Kraft Foods Inc. Plant.
- RBSanchez Inc. was also the HVAC system design consultant.





# WG&A RELIABILITY CENTERED MAINTENANCE SERVICES (RCM) CONSULTANCY w/ FB AMARRA SERVICES.



- FB AMMARA and RBSANCHEZ jointly serves the Consultancy for the WGA SHIPPING LINES Cargo Handling Improvement Systems Operations at the PORT, PIER 15, MANILA.

System consultancy for Improvement of availability and reliability of CARGO handling equipment of WG&A thru the DELMARINE CORP. for the nationwide expansion of shipping fleet of WG&A company (Year 2002-2003)



June-August 2002



# DESIGN OF NEW CHILLER, AHU AND CONTROL SYSTEM IN GLAXO SMITHKLINE INC. MEDICAL SUPPLIES

📍 Chino Roces Ave., Makati City



- RBSanchez was the HVAC system design consultant of the new Chiller plant and AHU systems, including the pipe and pumping system, fan coil units and control systems of Glaxo SmithKline Inc.






# NEW ANIBONG LEYTE SHELL ETHANOL PLANT

📍 Anibong, Tacloban, Leyte



- Mechanical Design and Consultancy of the new Anibong Depot Ethanol and Blending Storage Facilities for SHELL Depot facilities.





# DESIGN AND CONSULTANCY FOR NEW HVAC CHILLER PLANT OF STARMALL METROPOLIS

📍 Alabang, Muntinlupa, Metro Manila | June 2012



- RBSanchez Inc. is the HVAC Design Consultant of brand new 4500 TR Chiller Plant yielding to save a Php 3M – 4M per month in actual MERALCO bills as per Starmall records.






# DESIGN AND CONSULTANCY FOR NEW HVAC SYSTEM OF STARMALL EDSA

📍 Mandaluyong, Metro Manila | June 2012



- Design and Consultancy Services for the Upgrade of Chiller System for the 50,000 sqm commercial mall. RBSanchez Inc doing the complete design and consultancy services. The design yields to a monthly savings of Php. 1.5M on MERALCO bills as per Manuela records.





# RESIDENTIAL BUILDING HVAC DESIGN AND CONSULTANCY FOR SM BLOOM RESIDENCES



📍 SM Bloom Residences, Parañaque City | 2017

- RBSanchez is the HVAC system design engineer and consultant for the 450,546 sqm residential building of SM Bloom Properties from the Year 2016 to 2017.





# DESIGN AND CONSULTANCY OF CLEANROOMS FOR SMDC SHOWROOMS AT FMC PROPERTY

📍 Chino Roces Avenue, Makati, Metro Manila | 2016

- Complete HVAC system design and consultancy services for the cleanroom designs of SMDC Showrooms at FMC Property.





# DESIGN AND CONSULTANCY FOR WHOLE HVAC SYSTEM OF ROBINSONS MALL SAN PEDRO



ROBINSONS LAND  
CORPORATION

YOUR DREAMS, OUR FOUNDATION.

📍 179 Manila S Road, San Pedro, Laguna | 2018

- RBSanchez Inc. is the HVAC Design Consultant for the 104,500 sqm mall building of Robinson's San Pedro.






# DESIGN AND CONSULTANCY OF NEW FIRE PROTECTION SYSTEM OF OFFICE TOWER AYALA 6780

📍 Ayala Avenue, Makati City, Manila



- Fire Protection System Design and Consultancy for the NEW Fire alarm and sprinkler, Fire Tank and Pump system of the 15-storey building as contracted by LANDEV Corp of RCBC Inc. Group.





# CONSULTANCY FOR TROUBLE SHOOTING AND RETROFIT DESIGN FOR HVAC SYSTEM OF CENTURY HOTEL

📍 FB Harrison St, Manila | 2005

- This project is the start of RBSanchez Inc. services as Design Consultant for many other projects for Century properties.



**CENTURY PARK SHERATON HOTEL**  
Trouble-shooting, Cooling Load Analysis and retrofit of the chilled-water HVAC system and AHU duct distribution. Successful completion of the project saved PHP8M from the ordered purchase of new units of AHUS.



Century Park Hotel  
AN ANA HOTEL

21st December, 2005

*"RBS Engineering Technologies (through the consultancy services of Engr Rosen Sanchez) was able to save our company PHP8.0 Million worth of new AHUs from being purchased. Our AHUs are 25 years old and were on the verge for replacement. RBSanchez suggested keeping the old AHUs but has recommended some changes. A year has passed now and the hotel is still cool using our old AHUs. This is even with the passing of the hottest summers of 2005"*

*"I know Mr. R.B. Sanchez applies in-depth design analysis and investigation but recommends practical solutions. His engineering skills, hands-on analytical approach and good engineering judgment is very valuable and hard to find these days."*

*Mauro 21 Dec 2005*

MR. EDGARDO NAKPIL  
Chief Engineer, CENTURY PARK HOTEL  
599 P. Ocampo St., 1004 Malate, Manila City, Philippines



# DESIGN AND CONSULTANCY FOR NEW HVAC SYSTEM OF AYALA MALL AND BPO IN BACOLOD



📍 Bacolod, Negros Occidental | July 2016

- RBSanchez Inc. is the HVAC Design Engineer and Consultant for the 13,353 sqm commercial Ayala Malls Bacolod in Negros Occidental.





# DESIGN AND CONSULTANCY OF HVAC FOR ONE SHANGRI-LA (OSP) TOWER AND MALL COMPLEX

📍 Ortigas Center, Mandaluyong, Metro Manila | 2009

*One*  
SHANGRI-LA PLACE



**MEINHARDT**  
PHILIPPINES, INC.

- RBS Engineering (now RBSanchez Inc) was sub contracted by Meinhardt Philippines Inc. for a special design and consultancy for HVAC services of One Shangri-La Towers.





# DESIGN AND CONSULTANCY FOR WHOLE HVAC SYSTEM OF ROBINSONS BOGO TERMINAL



📍 Cayang, Bogó City, Cebu | 2017

- RBSanchez Inc. is the HVAC System Design engineer and consultant for the whole air-conditioning system of Robinson's Place Bogó Terminal in Bogó City at Cebu.





# DESIGN AND CONSULTANCY FOR WHOLE HVAC SYSTEM OF ROBINSONS MALL PLACE ANTIQUE



📍 San Jose de Buenavista, Antique | 2016

- RBSanchez Inc. is the HVAC System Design engineer and consultant for the 18,242 sqm building at Robinson's Place Antique.





# DESIGN AND CONSULTANCY FOR WHOLE HVAC SYSTEM OF STARMALL LAS PIÑAS



📍 CV Starr Avenue, Las Piñas, Manila | June 2015

- RBSanchez Inc. is the HVAC Design Consultant for the 20,673 commercial mall building of Starmall Las Piñas.





# DESIGN AND CONSULTANCY FOR WHOLE HVAC SYSTEM OF STARMALL TALISAY CEBU

📍 Talisay, Cebu | September 2016



- RBSanchez Inc. is the HVAC Design Consultant for the 26,404 commercial mall building of Starmall Talisay at Cebu.





# DESIGN AND CONSULTANCY FOR WHOLE HVAC SYSTEM OF STARMALL MALOLOS



📍 Longos, Malolos, Bulacan | June 2016

- RBSanchez Inc. is the HVAC Design Consultant for the 30,654 sqm commercial mall building.





# DESIGN AND CONSULTANCY FOR UPGRADE OF THE STARMALL SAN JOSE DEL MONTE PHASE 2



📍 San Jose del Monte City, Bulacan | September 2015

- HVAC System Design Engineer and Consultant for the 15,503 sqm commercial building.





# DESIGN AND CONSULTANCY FOR THE HVAC SYSTEM AUDIT, RETROFITTING AND REDESIGN

📍 Quezon Ave, Diliman, Quezon City, M. Manila | 2018



- HVAC system assessment, retrofitting and redesign of the whole HVAC systems and upgrade.
- Serves as a consultant for the 18,673 mall building and its expansions.





# HVAC CONSULTANCY, OPERATIONS & MAINTENANCE SERVICES

## ■ RCBC CORPORATE BLDG THE FORT

25th St, Mckinley Hills, Taguig



RBS has own personnel deployed on-site from Years 2017-2020 on a 24/7/365 basis.



# CHILLED WATER SYSTEM AND AHU DISTRIBUTION RETROFITTING AT CENTURY PARK SHERATON HOTEL



- CENTURY PARK SHERATON HOTEL Retrofit of the chilled-water HVAC system and AHU duct distribution. project saved PHP8M from the ordered purchase of new units of AHUs. RBSanchez is the HVAC system design consultant of Century Park Hotel.







**Design of Fire Protection, Electrical & HVAC Ducted Systems of 19, 20, & 21ST FLOORS at PBCOM TOWERS, AYALA.**

(All disciplines)



## Design & Consultancy



**Filinvest Corporation, 1st, 2nd, 3rd Flr, COMPUTER & SERVER FARMS CyberGate Building, FILINVEST CITY**

**Technistock Corporation, PhilamLife Building, Ayala (All disciplines)**

**Linea Italia, Greenbelt 3 (All disciplines)**



**SHELL DESIGN FOR SHELL BUILDING (2003) (All disciplines).**



**MANDARIN HOTEL SMOKING ROOM VENTILATION**



**EAST WEST BANK OFFICES HVAC DESIGNS.** All bank branches designed nationwide (2002- 2004).



# Design & Consultancy for Retrofits



**CENTURY PARK SHERATON HOTEL** Trouble-shooting, Cooling Load Analysis and retrofit of the chilled-water HVAC system and AHU duct distribution. Successful completion of the project saved **PHP8M** from the ordered purchase of new units of AHUS.



**AVON MANUFACTURING PLANT, Batino Exit, South Superhighway.** The HVAC analysis, and retrofitting consultancy services for the AVON PLANT in Laguna.



**DRAGON MALL PROJECT – a MEP DESIGN** of a proposed 3-storey 30,000 sqm mall located at the Alabang Zapote Road, Las Pinas.



# Design & Consultancy for Retrofits



**DRAGON MALL PROJECT –  
DESIGN** of a proposed 3-storey  
30,000 sqm mall located at the  
Alabang Zapote Road, Las Piñas.



RBS did the design and consultancy  
of the HVAC (chilled water  
systems), FIRE PROTECTION.  
Mechanical Consultancy value:  
Paid PHP1.2M for the Mechanical  
HVAC design.





# Design & Consultancy for Fort Bonifacio Stopover Buildings

📍 The FORT. Taguig, Metro Manila

**DESIGN** of a 2-storey 4,000 sqm mall and gas station. Architect is Environments Collaborative, Inc,

RBS did the design and consultancy of the HVAC and FIRE PROTECTION, Genset. Year 2001

.





# DESIGN AND CONSULTANCY FOR NEW HVAC SYSTEM OF CITYMALL SURIGAO



📍 Surigao City, Surigao del Norte | February 2016

- Design and Consultancy Services for the HVAC systems of an 8,570 sqm commercial building of CityMall Surigao.





# DESIGN AND CONSULTANCY FOR NEW HVAC SYSTEM OF CITYMALL PAVIA

📍 Old Iloilo – Capiz Rd. Pavia, Iloilo | February 2016

- Design and Consultancy Services for the HVAC systems of a 9,989 sqm commercial mall building.

**CITYMall**  
Your Everyday Mall!





# ENERGY SAVINGS AND MAINTENANCE SERVICES



## ■ ROBINSONS MALLS MAGNOLIA

Aurora Boulevard, Q.C.

Supply of HVAC Consultancy and Trane  
Chillers Operators Maintenance Services from  
Year 2013-2019





# OPERATIONS & MAINTENANCE SERVICES

## ■ RCBC CORPORATE BLDG THE FORT

25th St, Mckinley Hills, Taguig



Supply of HVAC Consultancy and Chiller  
Operators and Maintenance Services  
from Year 2017-2020



# DESIGN AND CONSULTANCY OF HVAC SYSTEM FOR VARIOUS JOLLIBEE STORES

📍 Various Jollibee Stores Nationwide

- HVAC Design and consultancy services for various stores of Jollibee Corporation nationwide.



JOLLIBEE		
J8-Lipa Batangas	666.62	
J8-PNB Aurora	708.41	
J8-Waltermart Makati	263.51	
J8-Atimonan V2	360.50	
J8-Tungkong Mangga	767.01	
J8-SM City Batangas	305.40	
J8-LRT BacLaran	554.33	
J8-Ronquillo	758.70	
J8-Catarman	336.00	
J8-Puregold Deparo	442.61	
J8-Lachmi Davao	345.68	
J8-Tandang Sora	723.50	
J8-Waltermart Cabanatuan		335.95
J8-Petron Diego Silang	659.42	
J8-Maa Road	1,861.04	
J8-North Harbour	1,978.32	
J8-Sm Fairview Annex 2	275.33	
J8-Legarda Bustillos	1,359.80	
J8-SM Bicutan	278.58	
J8-Tanay	2,286.12	
J8-Molave	1,502.57	
J8-Tabul	936.99	
J8-Orion	387.15	
J8-Mexico	598.67	
J8-Mandaue	517.00	
J8-Oroquieta	272.17	
J8-Asturias	555.70	
J8-Lucena	314.43	
J8-Sto. Nino	319.70	
J8-One Mall SM Valenzuela		607.94
J8-Guagua	854.83	
J8-Sto. Tomas Pampanga	598.46	
J8-Caltex Canlubang	433.17	
J8-Waltermart Bel-air	302.60	
J8-Atimonan Quezon Province		2,578.49
J8-SM Valenzuela	405.00	
J8-Tumauini	620.35	
J8-Rosario La Union	749.02	
J8-Macapagal	739.65	
J8-Legarda Bustillos Phase 1		676.82
J8-Hermosa	854.83	
J8-Sto. Tomas V2	606.10	
J8-SM Jaro Iloilo	363.00	
J8-LRT BacLaran Total Revision		554.33
J8-Narvacan	365.77	
J8-Pasig Rotonda	316.59	
J8-Iponan Highway	361.31	
J8-Binalonan	831.80	
J8-P. Tuazon	676.69	
J8-SM Rosales Pangasinan		344.00
J8-San Pedro Sto. Tomas	578.49	





# DESIGN AND CONSULTANCY OF HVAC SYSTEM FOR VARIOUS JOLLIBEE STORES

📍 Various Jollibee Stores Nationwide



JOLLIBEE VARIOUS PROJECTS			
PROJECTS	AREA( sqm)	PROJECTS	AREA( sqm)
JOLLIBEE AURORA	477.42	JOLLIBEE MAA ROAD	1,861.04
JOLLIBEE WALTERMART	263.51	JOLLIBEE NORTH HARBOR	2,412.77
JOLLIBEE TUNGKONG MANGGA	767.01	JOLLIBEE SM FAIRVIE ANNEX	275.33
JOLLIBEE SM CITY BATANGAS	305.40	JOLLIBEE LERDA BUSTILLOS	1,753.40
JOLLIBEE DAVAO LACHMI	357.21	JOLLIBEE SM BICUTAN ANNEX	278.58
JOLLIBEE WALTERMART CABANATUAN	335.95	JOLLIBEE TANAY	2,286.12
JOLLIBEE RONQUILLO	758.70	JOLLIBEE MOLAVE	1,905.89
JOLLIBEE GAISANO CATARMAN	395.91	JOLLIBEE ORION	1,576.68
JOLLIBEE PUREGOLD DEPARO	442.61	JOLLIBEE CASUNTINGAN MANDAUE	2,108.27
JOLLIBEE TANDANG SORA	723.50	JOLLIBEE ATIMONAN	593.86
JOLLIBEE PETRON DIEGO SILANG	659.42		



# Design & Consultancy Services for Scaffolding of NAIA AIRPORT RAMP

📍 NINOY AQUINO TERMINAL 3 AIRPORT, Pasay City, Metro Manila



## **TERMINAL 3- NAIA AIRPORT CONSULTANCY for SAFETY STUDY OF ELEVATED ACCESS SCAFFOLD DESIGN ( ear 2001)**

RBS predicted the PHP50M collapse and damage of Terminal 3 Access Road undertaken by Wiley Australia and Takenaka Corp. Engr Rosen B Sanchez used the RBS copyrighted “SCAFFPRO Software” for stress and strength analysis of the structures.

EEI Corp purchased the US\$5,000 from RBS software hereinafter in 2002.



# DESIGN AND CONSULTANCY FOR NEW HVAC SYSTEM OF CITYMALL BULUA CDO

📍 Cagayan de Oro. Misamis Oriental | August 2015



- Design and Consultancy Services for the HVAC systems of an 8,726 sqm commercial mall building in Cagayan de Oro.





# DESIGN AND CONSULTANCY FOR NEW HVAC SYSTEM OF CITYMALL ISULAN



📍 Tacurong City Rd., Isulan, Sultan Kudarat | August 2015

- Design and Consultancy Services for the HVAC systems of an 8,160 sqm commercial mall building in Sultan Kudarat.





# DESIGN AND CONSULTANCY OF HVAC & KITCHEN VENTILATION FOR VARIOUS CHOWKING STORES

📍 Various Chowking Stores Nationwide



- HVAC Design and consultancy services for various stores of Chowking nationwide.



## CHOWKING

CK-Commonwealth	
CK-Buhangin Davao	324.89
CK-Green Meadows	431.05
CK-Roxas Isabela	306.02
CK-GMA Cavite	381.00
CK-San Nicolas	241.18
CK-Matina	356.66
CK-Valenzuela City Hall	430.08



# DESIGN AND CONSULTANCY OF HVAC & KITCHEN VENTILATION FOR VARIOUS CHOWKING STORES

📍 Various Chowking Stores Nationwide



- HVAC Design and consultancy services for various stores of Greenwich Stores nationwide.



## GREENWICH

GW-Cabahug	285.48
GW-Dahlia Fairview QC	347.78
GW-Green Meadows	482.19
GW-Muntinlupa City Hall	362.52
GW-Taytay Uptown	170.79
GW-Valencia	285.65

JB-Balayan Stop Over 587.36



# VARIOUS DESIGN AND CONSULTANCY FOR WHOLE HVAC SYSTEM



📍 Various Locations

- **GLAXO SMITHKLINE INC. OFFICES IN PASONG TAMO, MAKATI.** Design and Installation of new chiller system, pipe and pumping system, AHUs, FCUs, and control system. August 2013.

**HTMI CALL CENTER PROJECT, Libis, Quezon City, Metro Manila.** – the design and construction consultancy of a 2-storey 3,000 sqm new call center building in The HVAC system was designed and constructed by Trane Phils. RBSanchez served as the design consultant of Trane Philippines for the design, construction and commissioning works of the project. (June 2005 to Feb 2006). Contract value awarded to RBSanchez: PHP1.05M for Mechanical design.



# VARIOUS DESIGN AND CONSULTANCY FOR WHOLE HVAC SYSTEM



📍 Various Locations

■ **MEGAWORLD CORP. FORBESWOOD PROJECT.** the design and consultancy for the RETAIL PROJECTS in Burgos Circle, the Fort. Design of HVAC Aircon, All HVAC ducting, and ventilation works and all related accessories. (May 2010 –July 2010).




**KINGS COURT RETROFITTING PROJECT, Makati City.** the redesign, consultancy and commissioning of the new AHU and associated systems for Ground floor, 2<sup>nd</sup>, 3<sup>rd</sup>, 4<sup>th</sup>, 5<sup>th</sup> and 6<sup>th</sup> floors, 500 tons total and effects on chiller units as well as associated ducting and accessories. To address moisture problems and chiller problems (July 2010- Aug 2010).

**ADDITIONAL SHELL ETHANOL STORAGE FACILITIES,** The design of Shell Depot, Ethanol and Blending Storage Facilities in Cabadbaran, Agusan, Mindanao, The design includes pumping stations, piping and tanks and loading gantry system. (June 2010 – August 2010).



VARIOUS CFD PROJECTS

# CFD DESIGN AND CONSULTANCY








## CONSULTANCY SERVICES FOR BALARA WATER TREATMENT PLANT 1

Solver: OpenFOAM v1902 – driftFluxFoam  
Post-processing: Paraview

CFD simulation to predict the sedimentation through the basins and sludge accumulation. The results to be used as a confirmatory for design and reference for sludge pumping system. This includes parametric study of bed slopes and sludge pump pit intervals in the reference of velocity profile, effluent turbidity quality and concentration prediction along the depth of the basin.







# CONSULTANCY SERVICES FOR BALARA WATER TREATMENT PLANT 1




Figure 8. Sludge bed development after t hours




Figure 10. Sludge concentration along basin depth at different sections,  $t = 24$  hours

## OPTIMAL AND COST-EFFECTIVE SLOPE AND SUMP PIT INTERVALS

Using measurements and results of the CFD model, the recommendation is to have a basin bed slope of 1:300 at sump pit intervals every 60 meters. These figures were realized after series of parametric studies and cost effective solutions analysis.



### Analysis of Gravity Induced Sludge Collection and Removal for Sedimentation Basin 1 and 2 of Balara Treatment Plant 1

RBSanalyzer PME Consultants and Associates Inc.<sup>1</sup>

<sup>1</sup>RBSanalyzer Engineering Department, Makati Executive Tower 2, Makati, Manila  
Website: [www.rbs-engineers.com](http://www.rbs-engineers.com)

#### Executive Summary

Proposed sludge removal method for two continuous sedimentation basins was investigated prior to retrofitting. The initial system includes three sump pumps in pits at 60-m interval along the 180-m basin. The floor were sloped at 1:300 for gravity induced sludge transport.

CFD simulations were conducted to determine the behavior of pertinent parameters such as flow field, sludge detention, basin dimensions, sludge zone depth and rheological properties both for the accumulation period and during sludge removal operation. OpenFOAM solver *driftFoam* was employed to perform the calculation for mass and momentum conservation for two-phase flow as a mixture. Applying the mixture model, water was set as the continuous phase and the settle-able sludge as dispersed phase. Furthermore, the sludge was modeled as a non-Newtonian fluid with rheological properties similar to bingham plastic. Measurements and validation tests were conducted to verify numerical solver predictions. Caution was exercised in using available data on best effort basis to represent actual site conditions.

The following items are summarized as the findings and corresponding recommendation, as proposed:

1. Gravity-induced transport of sludge to the sump by floor slope of 1:300 is insufficient. The initial design for sludge collection and removal will not be effective for long term operation. In this slope, the transport is very minimal that the sludge were accumulated in the interval span even after sludge pump operations.  
**Recommendation:** Increasing the slope to 1:150 to improve sludge transport without significant effect to the sedimentation process. Although, steeper slopes were observed to greatly improve the transport than 1:150 and shown in the concentration curves. Partial velocity disturbance and minor eddy formation may occur in the basin floor that may cause partial re-suspension in the floor depth.
2. Shortened distance between sump pits will improve the sludge collection and removal. Aside from increasing the slope, another parametric study findings in decreasing the interval was observed. It was observed that shortening the intervals significantly increases the collection rate overall as the area of removal is proportionally increased. However, further decreasing the interval may incur higher operational cost and maintenance cost as the sludge pumps would require regular maintenance due to its purpose.  
**Recommendation:** In-depth cost analysis are not included in this tender. Considering operational and maintenance cost, it is still recommended to reduce the interval up to 45-meter interval from the 60-interval. It is necessary to test run sludge operation to set optimum interval for each section of the basin so that issues previously discussed are avoided.
3. The study were set to consider an initial inlet of 300 NTU turbidity condition, as provided to be one of the highest in record. The study considered also a 100 NTU computational domain, however yields to insignificant findings difference compared to the 300 NTU domain, thus is not pursued further.
4. Adjust the floor slope of the sump pit section towards the pump base accordingly, to allow sludge movement in the sump pit to be drawn towards the pump and ensure sludge transport from the sides of the pit.
5. Selected pump specification (capacity and TDH) suffices as the sludge pump is operated intermittently to draw sludge out of the basin. In addition, verify the pump's capability at fluid viscosity.

Continuous Sedimentation CFD Analysis (RBS)

REF: 15-2018-RBS-CH-SED-BAS-CFD-000A

Written by  
RBS Data Team

© 2020. Owned and produced by RBSanalyzer PME Consultants and Associates Inc.





## Analysis of Gravity Induced Sludge Collection and Removal for Sedimentation Basin 1 and 2 of Balara Treatment Plant 1

RBSanchez PME Consultants and Associates Inc.<sup>1</sup>

<sup>1</sup>RBSanchez Engineering Department, Makati Executive Tower 2, Makati, Manila  
Website: [www.rbs-engineers.com](http://www.rbs-engineers.com)

### Executive Summary

Proposed sludge removal method for two continuous sedimentation basins were investigated prior to retrofitting. The initial system includes three sump pumps in pits at 60-m interval along the 180-m basin. The floor were sloped at 1:300 for gravity induced sludge transport.

CFD simulations were conducted to determine the behavior of pertinent parameters such as flow field, sludge detention, basin dimensions, sludge zone depth and rheological properties both for the accumulation period and during sludge removal operation. OpenFOAM solver driftFluxFoam was employed to perform the calculation for mass and momentum conservation for two-phase flow as a mixture. Applying the mixture model, water was set as the continuous phase and the settle-able sludge as dispersed phase. Furthermore, the sludge was modelled as a non-Newtonian fluid with rheological properties similar to bingham plastics. Measurements and validation tests were conducted to verify numerical solver predictions. Caution was exercised in using available data on best effort basis to represent actual site conditions.

The following items are summarized as the findings and corresponding recommendation, as proposed:

- Gravity-induced transport of sludge to the sump by floor slope of 1:300 is insufficient.** The initial design for sludge collection and removal will not be effective for long term operation. In this slope, the transport is very minimal that the sludge were accumulated in the interval span even after sludge pump operations.  
**Recommendation: Increasing the slope to 1:150 to improve sludge transport without significant effect to the sedimentation process. Although, steeper slopes were observed to greatly improve the transport than 1:150 and shown in the concentration curves. Partial velocity disturbance and minor eddy formation may occur in the basin floor that may cause partial re-suspension in the floor depth.**
- Shortened distance between sump pits will improve the sludge collection and removal.** Aside from increasing the slope, another parametric study findings in decreasing the interval was observed. It was observed that shortening the intervals significantly increases the collection rate overall as the area of removal is proportionally increased. However, further decreasing the interval may incur higher operational cost and maintenance cost as the sludge pumps would require regular maintenance due to its purpose.  
**Recommendation: In-depth cost analysis are not included in this tender. Considering operational and maintenance cost, it is still recommended to reduce the interval up to 45-meter interval from the 60-interval. It is necessary to test run sludge operation to set optimum interval for each section of the basin so that issues previously discussed are avoided.**
- The study were set to consider an initial inlet of 300 NTU turbidity condition, as provided to be one of the highest in record.** The study considered also a 100 NTU computational domain, however yields to insignificant findings difference compared to the 300 NTU domain, thus is not pursued further.
- Adjust the floor slope of the sump pit section towards the pump base accordingly, to allow sludge movement in the sump pit to be drawn towards the pump and ensure sludge transport from the sides of the pit.
- Selected pump specification (capacity and TDH) suffices as the sludge pump is operated intermittently to draw sludge out of the basin. In addition, verify the pump's capability at fluid viscosity.

Continuous Sedimentation CFD Analysis (2020)

REF: 11.2019/RBS-CM-SED-04S-CFD-000A

Written by  
Drex Delta Torre

© 2020. Owned and produced  
by RBSanchez PME Consultants  
and Associates Inc.

### A Numerical Solver for the Hydrodynamics of Sedimentation Process

OpenFoam solver driftFluxFoam was employed to perform the calculation for mass and momentum conservation for two-phase flow as a mixture. Applying the mixture model, water was set as the continuous phase and the settle-able sludge as dispersed phase. Furthermore, the sludge was modelled as a non-Newtonian fluid of rheological properties that behaves similar to bingham plastics.

**Mixture Continuity Equation** By assuming multi-phase flow as a pseudo multi-phase mixture, only one set of governing equations is needed in solver 'driftFluxFoam'. They are continuity equation and momentum equation for mixture and a continuity equation for dispersed phase. Theoretically, continuity and momentum equations can be derived from Eulerian-Eulerian model (Brennan 2001). Considering a two-phase flow, one phase is continuous basefluid and the other phase consists of dispersed solid particles. A continuity equation is required for each of the two phases:

$$\frac{\partial (\phi_f \rho_f)}{\partial t} + \nabla \cdot (\phi_f \rho_f U_f) = 0 \quad (1)$$

$$\frac{\partial (\phi_s \rho_s)}{\partial t} + \nabla \cdot (\phi_s \rho_s U_s) = 0 \quad (2)$$

where  $\rho_f$  and  $\rho_s$  are the densities of continuous phase and dispersed solid phase, respectively.  $\phi_f$  and  $\phi_s$  are the volume fractions of continuous phase and dispersed solid phase, respectively.  $U_f$  and  $U_s$  the velocities of continuous phase and dispersed solid phase, respectively.

If added (1) to (2), the result can be written as:

$$\frac{\partial (\phi_f \rho_f + \phi_s \rho_s)}{\partial t} + \nabla \cdot (\phi_f \rho_f U_f + \phi_s \rho_s U_s) = 0 \quad (3)$$

For the two-phase mixture, key properties and flow features can be estimated using (Ishii and Grolmes, nd):

$$\rho_m = \phi_f \rho_f + \phi_s \rho_s \quad (4)$$

$$U_f = U_{fm} + U_m \quad (5)$$

$$U_s = U_{sm} + U_m \quad (6)$$

$$\phi_f \rho_f U_{fm} + \phi_s \rho_s U_{sm} = 0 \quad (7)$$

where  $U_{fm}$  and  $U_{sm}$  are relative velocities of continuous phase and dispersed solid phase to the mixture, respectively.  $U_m$  is the velocity of the mixture.

Then the contents in the second bracket of (3) can be rewritten as:

$$\phi_f \rho_f U_{fm} + \phi_s \rho_s U_{sm} = \rho_m U_m \quad (8)$$

Therefore, (3), the continuity equation for the two phases can be written in a very similar form as that for a normal single phase flow:

$$\frac{\partial \rho_m}{\partial t} + \nabla \cdot (\rho_m U_m) = 0 \quad (9)$$

In solver 'driftFluxFoam', (9) is not used directly in any header files. However, it will be used implicitly in file 'pEqn.H' for pressure-velocity correction.

**Mixture Momentum Equation** Momentum equations for continuous and dispersed solid phases can be given as:



For the two-phase mixture, key properties and flow features can be estimated using (Ishii and Grolmes, nd):

$$\rho_m = \phi_f \rho_f + \phi_s \rho_s \quad (4)$$

$$U_f = U_{fm} + U_m \quad (5)$$

$$U_s = U_{sm} + U_m \quad (6)$$

$$\phi_f \rho_f U_{fm} + \phi_s \rho_s U_{sm} = 0 \quad (7)$$

where  $U_{fm}$  and  $U_{sm}$  are relative velocities of continuous phase and dispersed solid phase to the mixture, respectively.  $U_m$  is the velocity of the mixture.

Then the contents in the second bracket of (3) can be rewritten as:

$$\phi_f \rho_f U_{fm} + \phi_s \rho_s U_{sm} = \rho_m U_m \quad (8)$$

Therefore, (3), the continuity equation for the two phases can be written in a very similar form as that for a normal single phase flow:

$$\frac{\partial \rho_m}{\partial t} + \nabla \cdot (\rho_m U_m) = 0 \quad (9)$$

In solver 'driftFluxFoam', (9) is not used directly in any header files. However, it will be used implicitly in file 'pEqn.H' for pressure-velocity correction.

**Mixture Momentum Equation** Momentum equations for continuous and dispersed solid phases can be given as:

**Free Surface** For free surface, symmetry boundary is applied here. Similar to zeroGradient for scalars, the normal component is set to zero for vectors.

**Physical Properties of Activated Sludge** Sewage sludge exhibits Bingham Plastic behaviour as was shown from several studies. Two quantities need to be specified in order to characterise this rheology, namely the yield stress,  $\tau_y$ , and the plastic viscosity,  $\eta$ . A constitutive relationship for settling velocity is also needed in order to carry out numerical simulations with the Drift Flux model.

Yield stress and plastic viscosity vary with concentration. Various authors as reviewed by (Casey and Newman 1983), have formulated exponential relationships for these quantities. They have the general form;

$$\Phi = a C^{ba} \quad (21)$$

where  $\Phi$  is the physical property in question,  $\alpha$  is the solids fraction and  $a$  and  $b$  are constants. The exponent  $\text{stet}$ ,  $C$ , is generally the natural logarithm base  $e$ , or the base 10.

The exponent from the experimentally derived settling velocity can be adjusted using equation 22. This essentially scales the physical properties of the sludge used in initial cases for other experiments.

$$\Phi = a C^{\frac{\alpha_f n - 0.002}{\alpha_n} ba} \quad (22)$$

The coefficients used for the calculation of sludge properties from are summarized in Table 2 - 5. Several sets of sludge properties have been opted to determine extent of effects of their properties to the workability of the proposed sludge removal method. Since there are no sludge scrapers to be installed, sludge displacement have been left virtually on gravitational effects induced by basin floor sloping.

**Table 2.** Coefficients used to estimate sludge properties

Property	Coefficient a		Exponent b	
			$\alpha_f n = 0.001$	$\alpha_f n = 0.002$
Yield Stress	5.55E-05	kg/(m.s <sup>2</sup> )	1050.8	951.25
Bingham Viscosity	2.31E-04	kg/m.s	179.26	179.26
Settling Velocity	-2.20E-03	m/s	285.84	285.84

**Table 3.** Coefficients used to estimate sludge properties (low density)

Property	Coefficient a		Exponent b	
			$\rho_d = 1042 \text{ kg/m}^3$	
Yield Stress	5.55E-05	kg/(m.s <sup>2</sup> )	39.95	
Bingham Viscosity	2.31E-04	kg/m.s	7.35	
Settling Velocity	-2.20E-03	m/s	12.97	

**Table 4.** Coefficients used to estimate sludge properties (medium density)

Property	Coefficient a		Exponent b	
			$\rho_d = 2000 \text{ kg/m}^3$	
Yield Stress	5.55E-05	kg/(m.s <sup>2</sup> )	951.25	
Bingham Viscosity	2.31E-04	kg/m.s	179.26	
Settling Velocity	-2.20E-03	m/s	285.84	





# CONSULTANCY SERVICES FOR BALARA WATER TREATMENT PLANT 1




Figure 8. Sludge bed development after t hours




Figure 10. Sludge concentration along basin depth at different sections,  $t = 24$  hours

## OPTIMAL AND COST-EFFECTIVE SLOPE AND SUMP PIT INTERVALS

Using measurements and results of the CFD model, the recommendation is to have a basin bed slope of 1:300 at sump pit intervals every 60 meters. These figures were realized after series of parametric studies and cost effective solutions analysis.



### Analysis of Gravity Induced Sludge Collection and Removal for Sedimentation Basin 1 and 2 of Balara Treatment Plant 1

RBSanalyzer PME Consultants and Associates Inc.<sup>1</sup>

<sup>1</sup>RBSanalyzer Engineering Department, Makati Executive Tower 2, Makati, Manila  
Website: [www.rbs-engineers.com](http://www.rbs-engineers.com)

#### Executive Summary

Proposed sludge removal method for two continuous sedimentation basins was investigated prior to retrofitting. The initial system includes three sump pumps in pits at 60-m interval along the 180-m basin. The floor were sloped at 1:300 for gravity induced sludge transport.

CFD simulations were conducted to determine the behavior of pertinent parameters such as flow field, sludge detention, basin dimensions, sludge zone depth and rheological properties both for the accumulation period and during sludge removal operation. OpenFOAM solver driftFluxFoam was employed to perform the calculation for mass and momentum conservation for two-phase flow as a mixture. Applying the mixture model, water was set as the continuous phase and the settle-able sludge as dispersed phase. Furthermore, the sludge was modeled as a non-Newtonian fluid with rheological properties similar to bingham plastic. Measurements and validation tests were conducted to verify numerical solver predictions. Caution was exercised in using available data on best effort basis to represent actual site conditions.

The following items are summarized as the findings and corresponding recommendation, as proposed:

1. Gravity-induced transport of sludge to the sump by floor slope of 1:300 is insufficient. The initial design for sludge collection and removal will not be effective for long term operation. In this slope, the transport is very minimal that the sludge were accumulated in the interval span even after sludge pump operations.  
**Recommendation:** Increasing the slope to 1:150 to improve sludge transport without significant effect to the sedimentation process. Although, steeper slopes were observed to greatly improve the transport than 1:150 and shown in the concentration curves. Partial velocity disturbance and minor eddy formation may occur in the basin floor that may cause partial re-suspension in the floor depth.
2. Shortened distance between sump pits will improve the sludge collection and removal. Aside from increasing the slope, another parametric study findings in decreasing the interval was observed. It was observed that shortening the intervals significantly increases the collection rate overall as the area of removal is proportionally increased. However, further decreasing the interval may incur higher operational cost and maintenance cost as the sludge pumps would require regular maintenance due to its purpose.  
**Recommendation:** In-depth cost analysis are not included in this tender. Considering operational and maintenance cost, it is still recommended to reduce the interval up to 45-meter interval from the 60-interval. It is necessary to test run sludge operation to set optimum interval for each section of the basin so that issues previously discussed are avoided.
3. The study were set to consider an initial inlet of 300 NTU turbidity condition, as provided to be one of the highest in record. The study considered also a 100 NTU computational domain, however yields to insignificant findings difference compared to the 300 NTU domain, thus is not pursued further.
4. Adjust the floor slope of the sump pit section towards the pump base accordingly, to allow sludge movement in the sump pit to be drawn towards the pump and ensure sludge transport from the sides of the pit.
5. Selected pump specification (capacity and TDH) suffices as the sludge pump is operated intermittently to draw sludge out of the basin. In addition, verify the pump's capability at fluid viscosity.

Continuous Sedimentation CFD Analysis (RBS)

REF: 15-2018-RBS-CH-SEC-BAS-CFD-000A

Written by  
RBS Data Team

© 2020. Owned and produced by RBSanalyzer PME Consultants and Associates Inc.



# ENVIRONMENTAL ASSESSMENTS OF ALL MAYNILAD PUMPING STATIONS




📍 Maynilad Pump Stations in West Manila and Cavite | 2019

- RBSanchez Inc. is the Mechanical Consultant for the Maynilad Water HVAC and Environments System Assessments, measurements and Analysis of Building of pumping stations.



**RBSANCHEZ PME CONSULTANTS & ASSOCIATES, INC.**  
• TECHNICAL ANALYSIS • DESIGN & CONSTRUCTION • TEST & MEASUREMENTS  
 "PROVEN, RELIABLE AND COST-EFFECTIVE SOLUTIONS"

## VILLAMOR PUMPING STATION AND RESERVOIR (VIL PSR) WORK ENVIRONMENT MONITORING REPORT






# ENVIRONMENTAL ASSESSMENT OF PUMPS STATIONS



📍 Maynilad Pump Stations in Manila and Cavite | 2019






# CONSULTANCY SERVICES AND PUMP PERFORMANCE ASSESSMENT of MAYNILAD PUMP STATIONS



📍 Maynilad Pump Stations in Metro Manila and Cavite | December 2018 to October 2019

- RBSanchez Inc. is the Mechanical Consultant for the Maynilad Water System Assessments, measurements and analysis for 120 pumping units in various pumping stations to 1100 hp water pumps.







# RBS contributes to the CFD designs for the TALLEST BUILDING IN THE WORLD

“WORLD’S TALLEST BUILDING” THE BURJ KHALIFA TOWER Dubai, UAE.

ARMANI HOTEL HVAC DESIGN. The only Armani branded Hotel in the world.



- Engr RBSanchez served as “HVAC DESIGN MANAGER”
- Engr. Rosen Sanchez is the official signatory of all Khalifa Bldg HVAC and CFD construction drawings in the Year 2006-2007.





# Actual CFD Simulations

**CFD FOR FLUE GAS  
MODELLING**

OF

**SHELL REFINERY IN TABANGAO,  
BATANGAS**

Done by RBS ASSOCIATE

**ENGR FRANCISCO AMARRA**




# CFD FOR REFINERY GAS EMISSIONS IN SHELL TABANGAO REFINERY

Program: AERMOD and AERMET

CFD analysis done by our associate Engr Francisco Amarra to study the  $\text{SO}_2$  and  $\text{NO}_x$  concentrations from stack emissions in the Shell Tabangao Refinery


## Input Data Required for AERMOD:

- Meteorological Pathways
  - Site data for surface climate & upper air stations
  - Study site data
- Surface Parameters
  - Albedo, Bowen ratio, surface roughness
- AERMAP
  - Terrain files converted to USGS-DEM format
- AERMET
  - Raw data: Surface Climate } Surface File
  - Raw data: Upper Air } Profile File



## INPUTS AND DATA GATHERING ON THE TOPOGRAPHY

Detailed study in the area of study were conducted including the terrain mapping around the refinery using available data from different sources.













# CFD FOR REFINERY GAS EMISSIONS IN SHELL TABANGAO REFINERY

## CONCLUSION

- Shell Tabangao Refinery emission concentrations were below the regulatory limits.
- Problems were encountered during acquisition of raw data:
  - Surface climate data not in required format;
  - Upper air climate data is not always available due to budget limitations
  - Terrain data is not readily available and expensive to produce.
- Conversion of raw data was successful. AERMOD program is applicable in the Philippines and was successfully applied using the Shell Tabangao Refinery.

## RECOMMENDATION

- **Air Dispersion Models** – EMB should focus on encouraging industries to make use of air modeling programs.
- **Surface and Upper Climatological Data** – bring up-to-date all encoding requirements for surface data and convert to CD-144 format: including encode of upper air data into CLICOM system and convert to TD-6201 formats
- **Terrain Data** – NAMRIA should develop digitized map in USGS-DEM format.







COMPUTERIZED FLUID DYNAMICS  
(CFD) STUDIES  
of  
ZAMA PRECISION DIE-CASTING LINES

By:




**RBSANCHEZ PME CONSULTANTS  
& ASSOCIATES, INC.**

• MECHANICAL ENGINEERS • DESIGN • HVAC OPERATIONS & STUDIES

[WWW.RBS-ENGINEERS.COM](http://WWW.RBS-ENGINEERS.COM)

---





## CFD ANALYSIS OF ALUMINUM-DIE CAST WAREHOUSE AT ZAMA PRECISION


Solver: Fire Dynamic Simulation (FDS) Ver 6 and SmokeView and PyroSim

CFD simulation to solve the smog and high particle concentration PM2,5 inside the warehouse. Different options were designed and simulated to best address the air quality, including additional upper vents and enlargement of lower vents to follow natural buoyancy laws, cross-flow ventilations and local push-pull option as recommendation.




### NO "CROSS VENTILATION" AT THE NORTHERN SIDE OF THE WAREHOUSE


Current velocity measurements shows that the air is only recirculating "plan-wise" (and not exhausting) across the building in the northern side near the furnaces.








## CFD ANALYSIS OF ALUMINUM-DIE CAST WAREHOUSE AT ZAMA PRECISION



### AVERAGE WIND SPEED OVER THE YEAR

This is the mean monthly wind speed (meters per second)



### NO "CROSS VENTILATION" AT THE NORTHERN SIDE OF THE WAREHOUSE

As a recommendation, we recommended to take advantage of the natural wind power at 322,900 cfm.






## CFD ANALYSIS OF ALUMINUM-DIE CAST WAREHOUSE AT ZAMA PRECISION

### PARTICLE ACCUMULATION OCCURS AT GROUND LEVEL OUTSIDE THE BUILDING AT NORTHEASTERN SIDE


Particles on the rooftop tends to fall off due to the layout of the fans relative to the roof profile and the gooseneck exhaust layouts. As a standard, exhausted air and particles shall be vented to the atmosphere at high levels for proper dispersion. Particle readings show higher levels of PM2.5 matter in the area with 705 ug/m3 especially when furnace exhausts are in operation.











## CFD ANALYSIS OF ALUMINUM-DIE CAST WAREHOUSE AT ZAMA PRECISION



### COMMENT ON THE PROPOSAL TO COMPLETELY INSULATE THE WAREHOUSE TO REDUCE INTERNAL TEMPERATURES

We were invited to comment on the proposal of insulating the warehouse. We don't recommend the insulation in the attempt to lower the internal temperatures of the warehouse, as it will only cost money, time, and space and moreover, increase the internal temperatures (not decrease).

However, we recommended high "solar reflectance" radiant barriers coupled with "air/insulation" technologies.



# CFD CONSULTANCY SERVICES FOR DESIGN OF GLAS TOWER PROJECT

📍 Ruby St, Ortigas Commercial Center | Aug 2020



RBS is the HVAC System Design Engineer and PME Consultant. For the first double-glazed, triple Low-E glass tower in Ortigas @ 188-meter with are of 102,000 square meters.

Multi use building for BPOs, Offices and Hotel. (Year 2020)



RBSanchez Inc. is a long-term Asya Partner in Mechanical and Structural Design aspects of the Building.





# CFD DESIGN OF VISCOUS PUMPING SYSTEMS OF LA CARLOTA SUGAR REFINERY

📍 La Carlota Sugar Refinery, Negros Occidental | July 2020

- Tanks, Piping and pump design with Fluid Dynamics and CFD simulation to predict the VISCOUS FLUIDS behavior for molasses and magma pumping systems.



- RBSanchez Inc. is a long-term Partner with Global Horizons Inc. in various industrial projects.





Actual CFD  
Simulations  
performed to date

FESTIVAL EXPANSION  
SUPERMALL

Alabang, Muntinlupa








## CFD ANALYSIS OF 5400-TR COOLING TOWER AT NEW FESTIVAL SUPER MALL


Different CFD schemes for the multiple configurations of the cooling towers based on orientation and layout arrangements. This includes single line tower configuration, separated towers at different tower orientation against prevailing wind direction.



**WIND DIRECTION**

### OPTION 1 – SINGLE LINE TOWERS CONFIGURATION AT 90DEG AGAINST THE WIND

Results show that abnormal backflow occurs at the back side of the cooling towers suction influenced by the suction of the tower flows.









## CFD ANALYSIS OF 5400-TR COOLING TOWER AT NEW FESTIVAL SUPER MALL

### OPTION 2 – SEPARATED TOWERS CONFIGURATION AT 90DEG AGAINST THE WIND

Same configurations except that the towers are separated to allow natural wind to flow between towers. Although improved airflow is observed in this case, abnormal pressure changes can still be observed in the back side of the towers suction.



WIND DIRECTION









## CFD ANALYSIS OF 5400-TR COOLING TOWER AT NEW FESTIVAL SUPER MALL

### OPTION 2 – SEPARATED TOWERS CONFIGURATION AT 90DEG AGAINST THE WIND

Similar results are observed compared to option 1. However, this configuration resulted to less disturbed airflow at the back side of the tower influenced by the tower fans suction effect.



WIND DIRECTION








## CFD ANALYSIS OF 5400-TR COOLING TOWER AT NEW FESTIVAL SUPER MALL


Different CFD schemes for the multiple configurations of the cooling towers based on orientation and layout arrangements. This includes single line tower configuration, separated towers at different tower orientation against prevailing wind direction.



**WIND DIRECTION**

### OPTION 1 – SINGLE LINE TOWERS CONFIGURATION AT 90DEG AGAINST THE WIND

Aligned towers along the wind direction at one side of tower suction. This CFD run results to abnormal pressure changes on the back side due to the counter-acting forces from the wind blow and tower suction.








## CFD ANALYSIS OF 5400-TR COOLING TOWER AT NEW FESTIVAL SUPER MALL

### OPTION 3 – SEPARATED TOWERS CONFIGURATION AT 0DEG AGAINST THE WIND

Same configuration with the option 2 but with 0 degree orientation to the wind direction. In this configuration, the velocity profile shows good agreement and results at the downstream profile. Separation of towers and both suction faces results to almost uniform flow and acceptable pressure domains.



WIND DIRECTION








## CFD ANALYSIS OF 5400-TR COOLING TOWER AT NEW FESTIVAL SUPER MALL

### OPTION 3 – SEPARATED TOWERS CONFIGURATION AT 0DEG AGAINST THE WIND

This configuration shows good agreement compared to previous cases and options.

Additionally, this case shows most improved airflow profile upstream and downstream.

Thus, this option is the best configuration and was recommended to be tower layout and configuration.



WIND DIRECTION









## CFD ANALYSIS AND CALCULATION FOR TAGAYTAY HIGHLANDS NATURAL VENTILATION

Under roof solar shield with 13mm hot air gap for insulation, huge solar cap covers and cross flow air ventilation and high ridge vents.








## CFD ANALYSIS FOR AN UNDERGROUND SUPERMALL CARPARK TUNNEL

Solver: Fire Dynamic Simulation (FDS)

An underground road tunnel design for oxygen, car fire scenarios, carbon monoxide and carbon dioxide levels at such scenarios.

This tunnel design aims to determine the levels of dangerous pollutants that will occupy the tunnel and identify mitigating conceptual designs to counter the predicted conditions. This will also reduce the amount of time and money to be if such failure occurred in actual.








## CFD ANALYSIS FOR THE METROPOLIS MALL AIR CAVERN CATCHER FOR NATURAL VENTILATION


A 3600-TR mall natural ventilation study in the opening of the glass façade to accommodate and act as a wind catcher intake.




### PRINCIPLES OF NATURAL VENTILATION

Different airflow principles that follows the law of natural ventilation and buoyancy were adopted in this project.





## CFD ANALYSIS FOR THE METROPOLIS MALL AIR CAVERN CATCHER FOR NATURAL VENTILATION




### NATURAL VENTILATION – SPENT AIR


The use of the shuttered open the main hallways and corridors to serve as exit and entry of wind driven air. The use of spent cool air from the three lower floors to be released upward to assist in cooling the natural ventilation of 4<sup>th</sup> and 5<sup>th</sup> floors.

The design and provision (for occasional use during humid months) of swimming pool fountain as chilled water curtain air dehumidifier during hot and humid days to dry incoming air in the wind catcher intake. It is estimated in two to three months a year that the wind will be too hot and humid and need the cooling assistance from chilled water.







## CFD ANALYSIS FOR THE METROPOLIS MALL AIR CAVERN CATCHER FOR NATURAL VENTILATION



### NATURAL WIND PROFILE OVER THE AREA

The velocity and pressure profile over the buildings surrounding the malls. Study were conducted to determine the traverse air direction influenced by barriers.



### ROOF RIDGES DESIGNS



The design of the roof apex and ridges as wind-driven cross ventilation, where natural wind will be pushed and sucked out the hot air trapped in the roof level. The design acts as a cool air intake and hot air exhaust from the influence of wind driven pressures.







## CFD ANALYSIS FOR AN AIR COOLED CHILLER AIR INTAKE STUDY

A study of air-cooled chiller configuration and the intake velocity and temperature profile in the near and far-end intake planes.



### TEMPERATURE AND VELOCITY PROFILES

The results shows the velocity profiles (right) and temperature profiles (left) for the chiller intake and exhaust planes. The results agreed and validated the actual conditions on site.









## **OTHER CFD PROJECTS HANDLED**

- **Computer Server Farms and Server Rooms**
- **Industrial Plant Cleanrooms**
- **Healthcare Facilities and Cleanrooms**
- **Highrise Building Wind and Stack Effects**
- **Carpark and Underground Tunnels ventilation**
- **Underground Spaces**
- **Naturally Ventilation of Structures**
- **Kitchen Comfort and Hood Exhaust Design**




“AS DESIGNED” CFD RUN ON  
COOLING TOWERS  
NEW FESTIVAL SUPER MALL





## READINGS OF LOCAL VENTILATION PM2.5 PARTICLE CONCENTRATIONS





# OPERATIONS & MAINTENANCE (O&M)

---





# OPERATIONS & MAINTENANCE SERVICES

## FABRICATION PLANT 1

- Supply of HVAC Consultancy and Chiller Operations Maintenance Services. RBS supplied consultancy and technical operations staff on a 24/7/365 basis for Years 2007-2014. Laguna Technopark, 100, East Main Avenue, Binan City



Year 2007-2014



SUNPOWER®



# OPERATIONS & MAINTENANCE SERVICES

- **MODULE MANUFACTURING MODCO PLANT. SunPower Corporation** Supply of HVAC Consultancy and Chiller Plant Operations and Maintenance for MODCO.

RBS supplied consultancy and technical operations staff on a 24/7/365 basis Year 2007-2016 Module Manufacturing (SPMM) Plant Binan, Laguna.



SUNPOWER®



# OPERATIONS & MAINTENANCE SERVICES

- **ASCOTT HOTEL / GLORIETTA 4**
- Supply of HVAC Consultancy and Chiller Operations and Maintenance Services to Trane Phils. Inc, from Year 2007-2018
- 





# OPERATIONS & MAINTENANCE SERVICES

- **WELLS FARGO LLC** Wells Fargo Drive, McKinley Hill,  
Upper McKinley Road, Taguig City, Metro Manila



Supply of HVAC Consultancy and Trane Chiller Operators and Maintenance Services from Year 2017-2020



# OPERATIONS & MAINTENANCE SERVICES

## ■ RCBC CORPORATE BLDG THE FORT

25th St, Mckinley Hills, Taguig



Supply of HVAC Consultancy and Trane  
Chiller Operators and Maintenance Services  
from Year 2017-2020



# OPERATIONS & MAINTENANCE SERVICES

- Makati Medical Center

Ayala, Makati



- Supply of HVAC Consultancy and Chiller Operation and Services to Trane Phils. Inc. 2007-2013





# MAINTENANCE SERVICES

## ■ GLAXO SMITH KLINE

Chino Roces Avenue, **Pasong Tamo** Ext. Makati City



Supply of Maintenance  
Services from Year 2017-2019

RBS has personnel deployed  
on-site.





# TESTING AND COMMISSIONING OF CHILLED WATER SYSTEM AND AIR SIDE AHUS FOR ST. LUKES HOSPITAL AT THE FORT



**St. Luke's**  
Medical Center  
Quezon City · Global City

📍 5<sup>th</sup> Avenue, Global City, Taguig, Metro Manila | 2008

- HVAC Test and Commissioning Services and Consultancy to TRANE Philippines Inc for Chillers and Medical AHU systems







ASSOCIATES,  
PARTNERS, ENGINEERS  
& STAFF



# ASSOCIATE DIRECTOR ROLANDO B. SANCHEZ



**STRUCTURAL CIVIL** An experienced Structural Engineer with more than 32 years of experience in design and analysis of high rise buildings up to 40-storey, industrial plants, oil refinery, mining, cement plants, communication towers, guyed tower, silos, piers, revetment structures, slope protection, rockfall analysis, civil works, mining primary crusher, etc. here and abroad.

Date	Position	Company
2001 – present	Managing Principal	RBSanchez Consulting Engineers
1996 – 2000	Structural Design Manager	R.S. Caparros and Associates
1992 – 1994	Rendered Structural Design Services	International Design Group – Canada
1989 – 1992	Structural Design Head	R.S. Caparros and Associates
1990 – 1992	Rendered Structural Design Services	Various Company
1987 – 1998	Structural Design Engineer	Design Management and Development Corporation



## EDUCATION

- **Advanced Structural Steel Design, Advanced Structural Analysis, Hydraulics and Hydrology, Engineering Economics**  
University of Toronto, Canada
- **Computer Aided Structural Analysis and Design**  
Seneca College, Canada
- **Bachelor of Science in Civil Engineering**  
University of Sto. Tomas



# ASSOCIATE PARTNER

## MARIO ALIX, PEE

Professional Electrical Engineer and Systems Specialist



### ● CORE SKILLS

1. Detailed Design Engineering
2. Electrical System and Analysis
3. Construction Project Management
4. Cleanrooms Electrical Provisions
5. Power Distributions
6. Industrial & Commercial Design and Applications

### Owner of Mario A. Alix Philippines, Inc.

- The Outstanding Mapuan (TOM) Awardee 2008 in Professional Practice in Electrical Engineering
- Institute of Integrated Electrical Engineers Awardee 2012 of The Most Outstanding Electrical Engineer

### ● EDUCATION

- Bachelor of Science in Electrical Engineering Mapua Institute of Technology, Manila

**RBSanchez PME Consultants & Associates, Inc.**



# ASSOCIATE PARTNER OSCAR RELUCIO

## PME (PROFESSIONAL MECHANICAL ENGINEER)



**BS IN MECH ENGG. - U.P. DILIMAN YEAR 1981**

### Major Experiences & Design

- Intel Technology Philippines, 2001-2007
- Amkor/Anam Phils Muntinlupa, 1991
- American Microsystems Phils. Inc., 1993
- Sunpower Phils. Inc. Fab1/Fab2 Line Expansion,
- Microsemi Semi-Conductors Manila, 2015
- 30,000sqm HSBC Data Center Project at Hongkong
- Mead Johnson (Phils) Inc., Johnson & Johnson (Phils), Inc.,
- Texas Instrument Phase 2 Bump Module Expansion, 2011
- Cypress Decatech Project Laboratory, 2010
- Procter & Gamble – Beijing
- Ford Motors Phils Inc.
- Bayer Headquarters
- Knauf Manufacturing Facility at Batangas
- Nestle Phils. Inc
- Astra Head Office and Pharmaceutical Plant Complex, 1989
- Malt Extract Plant, Lipa, Batangas
- St. Lukes's Medical Center, BGC Taguig City
- Philippine Orthopedic Center, Quezon City
- Taguig Hospital, Taguig City
- Eastern Visayas Regional Medical Center, Tacloban City
- Ospital ng Makati, Makati City
- Childrens Hospital, Pasig City
- Okada Manila, Paranaque City

Date	Position	Company
2019 – present	Associate Director	RBSanchez PME Consultants & Associates
1998 – 2019	Mechanical Director	Meinhardt Philippines, Inc.
1993 – 1998	Mechanical Head & Project Manager	PT Arnan Pratama Consultants
1989 – 1993	Mechanical Engineering Manager	RN Ferrer Associates,
1984 – 1986	Senior Mechanical Designer & Estimator	OV Roy Construction Inc.
1982 – 1983	Junior Mechanical Designer	Trans-Asia Philippines, Inc.
1981 – 1982	Junior Mechanical Estimator & Designer	Capitol Industrial Construction Group, Inc.

**RBSanchez PME Consultants & Associates, Inc.**



# ASSOCIATE PARTNER **DR. ENRICO C. NERA**

***UP Diliman B.S. in Metallurgical Engineering***

ASEAN Engg., APEC Engr., MSMEP, MAusIMM,  
Masters in SME, AFEO Honorary Fellow  
PRC Regulatory Board Member, Board of Metallurgical Engineering  
Past President and CEO, Atlas Consolidated Mining and Development Corp



July 2021 - current	Offshore Mining Operations Manager, RBSanchez PME Consultants Inc.
September 2015 - February 2020	CEO, President and CEO, Atlas Consolidated Mining and Development Corp.
September 2014 - February 2018	EVP-Operations & Chief Operating Officer Carmen Copper Corporation
July 2007 – Mar 2015	President and Chief Operating Officer Minercon International
November 2002 – June 2007	Professional Regulation Commission Board Member, Professional Regulatory Board of Metallurgical Engineering
1988–1993	Philex Mining Corp. Benguet, Philippines Sr. Metallurgist
1983–1988	Marcopper Mining Corp. Marinduque, Phil. Metallurgical Engineer

**RBSanchez PME Consultants & Associates, Inc.**



# ASSOCIATE PARTNER Hilbert M. Cardenas

ACP Met. E. (PMRC), MAusIMM



## Education

**Master of Management, 2004-2005**

**B.S. Metallurgical Engineering, 1986-1991 University of the Philippines, Diliman**

Metallurgical Plant Practice: Metals Industry Research and Development Center

**Second Placer in 1992 PRC Board Exam** for Metallurgical Engineer with a rating of 88%  
And **Registered Metallurgical Engineer** In the Professional Regulation Commission

**Experience.** Twenty (20) years of experience in Mining and Plant metallurgy in major corporations, Consultancy and Operations management inclusive of 15 years in senior roles, Five (5) of which in senior EXPATRIATE roles in Vietnam and Tanzania.

## Awards:

Outstanding Professional of the Year Award in the Field Of Metallurgical Engineering– PRC 2021

Professional Degree Award in Metallurgical Engineering – UP Alumni Engineers. 2021

Distinction Awardee in Metallurgical Engineering, Philippine Federation of Professional Associations Awards, 2022

DO-IT Award for Sustainability – OceanaGold Philippines Inc. 2017

**RBSanchez PME Consultants & Associates, Inc.**



## ASSOCIATE ENGINEER

# JOSE FRANCISCO R. SANCHEZ Mining Engineer / Specialist

Apex Mining Company, Incorporated, Mining Consultant – 2021

EHMC Consulting, Inc., Principal Geotechnical Engineer – 2019

Besra Gold Inc., Vietnam, Consultant and Project Manager – 2016

Besra Gold Inc., Malaysia, Senior Geotechnical Engineer – 2012 to 2014

Golder Associates, Australia, Senior Geotechnical Engineer – 2012

Olympus Pacific Minerals Inc., Malaysia, Environment Manager – 2010-2012

Kinbauri Gold Espana S.L., Spain, Chief Mining Engineer – 2008-2009

RRMI Lafayette Mining Ltd, Rapu-Rapu Mine, Mine Geotechnical Engineer – 2005

Lepanto Consolidated Mining Co., Senior Mining, Geotechnical Engineer – 1999–2005.

Philex Mining Corporation and Philex Gold Philippines Inc., Sibutad Project, Mining Engineer – 1996-1999



## EDUCATION

- **Board Topnotcher, 1<sup>st</sup> PLACER** in the 1996 Mining Engineering Licensure Examination
- **M.S. Civil Engineering, major in Geotechnical Engineering**, Mapua Institute of Technology. 2014-2015
- **B.S. Mining Engineering**. Mapua Institute of Technology. 1996.

**RBSanchez PME Consultants & Associates, Inc.**



## ASSOCIATE ENGINEER

# RAFAEL M. SANCHEZ BSCE Masters in Science Structural Engineering, Civil Engg. and CPEng Onshore/Offshore

MSc Oil and Gas Structural Engineering, University of Aberdeen, Scotland,  
2013

B.S., Civil Engineering, University of the Philippines, 2003

### SPECIAL AWARDS

14th Place	Out of over 6000 examiners in the National CE board exam	November 2003
Top Performer of the Month	MPP Project – Worleyparsons	February 2016
With commendation award	MSc in oil and gas structural Engineering	September 2013
Spotlight Award	DOW/PIC Olefins II Kuwait Project - Fluor	November 2006



2017 – 2020	Director / Senior Engineer – RMS Offshore Engineering Pty Ltd, Melbourne, Australia
2014 - 2017	Principal Civil and Structural Engineer - WorleyParsons, Al Khobar, Saudi Arabia
2008 - 2014	Civil and Structural Engineer – Woodgroup PSN, Melbourne, Australia
2005 - 2008	Civil and Structural Engineer – Fluor Corporation, Alabang, Philippines

**RBSanchez PME Consultants & Associates, Inc.**





**ENGINEERS & STAFF**



# **DIRECTOR of ENGINEERING**

## **Nick Johnsonn B. Fernandez, BSME**

### **President Ramon Magsaysay State University**



**PRC Mechanical Board Exams 2018**  
**Possible “12th PLACE”, Board Licensure Score of 92%.**

A WELL-ROUNDED Engineer who combines both theory and practical experience.

Excellent in complex math, programming in using **CFD tools such as Open Foam, RHINO, Arduino, Grasshopper, BREAM, IESVE and LEED** design, etc. down to ISO Cleanroom Class 100 and design of Server Farms, and final multi-discipline projects complete with testing and CX works, turover, maintenance and operations.

**Expert in the use of test equipment and measurements** to confirm CFD models for thermodynamics, hydrodynamics, environmental and CFD projects in IT SERVER airflows, heat island effects in cleanrooms in semiconductors, water treatment and chemical and sludge and viscuous slurries and mine processing plants.



# **ENGINEERING ASSOCIATE**

## **JOEY MICHAEL PEÑA PORTE**

### **PME (PROFESSIONAL MECHANICAL ENGINEER)**



## **PRC Mechanical Board Exams 1996**

### **Sixth (6th Placer) in the PRC Mechanical Engineer Board Licensure Examination**

- **University of Nueva Caceres** 1990-1995 Naga City, Philippines

#### **WORK EXPERIENCE:**

Mechanical Engineer - (HVAC, Plumbing , Drainage & Fire Fighting)

Construction Development Company ( CDC ) / ( 2008 – 2017 )

Doha, Qatar

2013 Ministry of Municipality in Urban Planning & Development Authority

Certified Mechanical Engineer – MM UPDA ( Qatar )- Grade “A”

2021 U.S. Army Corps of Engineers (USACE)

Al Udiel US Air Base – Qatar

Corps of Engineers and Naval Facility Engineering Command Training Course

Construction Quality Management (CQM) - Certified Mechanical Engineer

**RBSanchez PME Consultants & Associates, Inc.**



# MECHANICAL ENGINEER

**ROBERTO F. MENDOZA JR., M.E.**

**DON MARIANO MARCOS MEMORIAL STATE  
UNIVERSITY – MLUC**

**San Fernando City, La Union Bachelor of Science  
in Mechanical Engineering 1983 - 1988**

**Mechanical Package Superintendent  
PT Saipem Indonesia  
LNG Tangguh Expansion -Train 3  
March 14, 2021 – January 13, 2022**





# MECHANICAL ENGINEER

**KYLE ADRIAN APONESTO, ME**

**Mapua University**

**Bachelor of Science in Mechanical Engineering  
(2018-2022)**

**Board exam rating: 89.3**

**Skills: Autocad, Autodesk Fusion 360, Matlab**



**RBSanchez PME Consultants & Associates, Inc.**



# ADMIN MANAGER

**ROSE R. SABIO**



## **BACHELOR OF SCIENCE IN INFORMATION TECHNOLOGY**

**PHILIPPINE COLLEGE OF TECHNOLOGY(DAVAO CITY, 2012-2015)**

**COMPUTER HARDWARE SERVICING NC11  
ASIAN BUSINESS INSTITUTE OF E-TECHNOLOGY  
(BACOLOD CITY, 2008-2009)**

### **VIRTUAL ASSISTANT FOR 5 YEARS**

**\*MANAGER OF EBAY STORES IN AUSTRALIA, U.S.A AND U.K  
ACCOUNTS (RESPONSIBLE TO TRAIN OTHER VA, SET-UP BUSINESS POLICIES,  
SEARCH PROFITABLE PRODUCTS, CUSTOMER SERVICES, HANDLE PAYPAL  
DISPUTES, AND DAILY SALES OF THE ACCOUNTS)**

### **MCR Bles Foods Trading Co.**

**\*ENCODER FOR 6 MONTHS**

### **PHILIPPINE STATISTICS AUTHORITY**

**\*OJT ENCODER FOR 3 MONTHS**

**RBSanchez PME Consultants & Associates, Inc.**



## ADMIN EXECUTIVE

**Charo T. Tamayo**

**Administration Business  
Management (ABM)**

**AMA Education System**

**ABE International Business College  
Makati(2016-2019)**





## TECHNICAL ASSISTANT

**Cipriano T. Tamayo Jr.**

**Mechanical Field Technician  
Electrical-Acres Professional  
Institute Dagupan city (2009)**

**Experienced in Data gathering,  
logging and Instruments, IT,  
Electrical and Mechanical Field  
Technical Assistant**





# RBSANCHEZ PME CONSULTANTS & ASSOCIATES INC., PERSONNEL ORGANIZATIONAL CHART



RBSanchez PME Consultants & Associates, Inc.



## RESOURCE/OFFICES:



With complete Personnel Support and resources for:

1. AutoCad Drafting and Large format Plotting
2. Complete Engineering softwares (with license): Elite Duct Size 3.0, PsychartHD 7.4, Flite FluidFlow Pipe and Duct Ver 3.0., ASHREA Fundamentals 2013, Trace 700 Cooling Load, CHVAC Heat Load, PipeSizer, Autocad Suite 2013, Cloud computing, and a lot more.
3. Dedicated FTP site for large file transfer

**RBSanchez PME Consultants & Associates, Inc.**





**RBSanchez PME Consultants & Associates, Inc.**





**RBSanchez PME Consultants & Associates, Inc.**



# GOVERNMENT LICENCES AND REGISTRATION PAPERS





# S.E.C. AND BUSINESS PERMITS



REPUBLIC OF THE PHILIPPINES  
**SECURITIES AND EXCHANGE COMMISSION**  
SEC Building, EDSA, Greenhills  
City of Mandaluyong, Metro Manila

COMPANY REG. NO. CS201000511  
COMPANY TIN 007-570-182

**CERTIFICATE OF INCORPORATION**

KNOW ALL PERSONS BY THESE PRESENTS:  
This is to certify that the Articles of Incorporation and By-Laws of

**RBSANCHEZ PME CONSULTANTS & ASSOCIATES INC.**

were duly approved by the Commission on this date upon the issuance of this Certificate of Incorporation in accordance with the Corporation Code of the Philippines (Batas Pambansa Blg.68), and copies of said Articles and By-Laws are hereto attached.

This Certificate grants juridical personality to the corporation but does not authorize it to undertake business activities requiring a Secondary License from this Commission such as, but not limited to acting as: broker or dealer in securities, government securities eligible dealer (GSED), investment adviser of an investment company, close-end or open-end investment company, investment house, transfer agent, commodity/financial futures exchange/broker/merchant, financing company, pre-need plan issuer, general agent in pre-need plans and time shares/club shares/membership certificates issuers or selling agents thereof. Neither does this Certificate constitute as permit to undertake activities for which other government agencies require a license or permit.


As a registered corporation, it shall submit annually to this Commission the reports indicated at the back of this certificate.

IN WITNESS WHEREOF, I have hereto set my hand and caused the seal of this Commission to be affixed at Mandaluyong City, Metro Manila, Philippines, this 26<sup>th</sup> day of January, Twenty Ten.

  
**BENITO A. CATARAN**  
Director  
Company Registration and Monitoring Department





 **CITY OF MAKATI**  
BUSINESS PERMITS OFFICE  
**PAHINTULOT SA PANGANGALAKAL**  
(BUSINESS PERMIT)

PERMIT NO. **06579**  
06579


**MATALASTAS NG LAHAT:**  
(KNOW ALL MEN BY THESE PRESENTS)  
**NA SI / ANG:**  
(THAT)


**RBSANCHEZ PME CONSULTANTS & ASSOCIATES, INC.**  
na matatagpuan at may pahatirang sulat sa  
(with postal address at)  
**U-2807 28/F CITYLAND PASONG TAMO TOWER 2210 CHINO**  
na itinatag nang may bukasang pangangalakan ng mga batas ng  
(duly recognized and existing under the laws of the)  
**Republika ng Pilipinas, ay pinagkalooban ng pahintulot na mangelakal bilang**  
(Republic of the Philippines, is hereby granted the permit to operate as)

**SEO**  
ngayong ika- 05 ng January 2024  
(on this) (day of)

Ang pahintulot na ito ay matatapos sa ika- 31 of December 2024.  
(this permit expires on)

Malibang ito'y maagang bawlin at pawalang bisa.  
(unless sooner revoked)

  
**ATTY. MARIERT Q. PAGENTE**  
HEAD, BUSINESS PERMITS AND LICENSING OFFICE

  
**HON. MAR-LEN ABIGAIL S. BINAY**  
PUNONG PANGUNOD (CITY MAYOR)

TAX YEAR :	2024	QUARTER :	4
O.R. NO. :	47112268V	O.R. DATE :	01/05/2024
O.R. AMOUNT :	60,445.03		
MAYOR'S PERMIT FEE	4,000.00		
BUSINESS TAX	15,000.00		
SANITARY PERMIT FEE	90.00		
GARBAGE FEE	1,200.00		
SIGNBOARD FEE	200.00		
ENGINEERING FEE	0.00		
INDIVIDUAL MP FEE	1,000.00		
INDIVIDUAL HC FEE	1,600.00		
MEAT INSPECTION FEE	0.00		
FSI FEE	823.50		
BARANGAY CLEARANCE FEE	3,000.00		
OTHER FEES / PENALTY / INTEREST	33,531.53		
<b>TOTAL</b>	<b>60,445.03</b>		

**IMPORTANT**

Failure to renew this Business Permit within the prescribed period shall subject the taxpayer to a twenty-five percent (25%) surcharge and two percent (2%) penalty per month. Upon closure of business, surrender this permit to City Treasurer's Office on or before the twentieth (20th) day of the month following the quarter to avoid penalty.

201000737

**ITO AY DAPAT IPASKIL SA HAYAG NA POOK NG KALAKALAN AT DAPAT IPAKITA SA SANDALING HINGIN NG MGA KINAUKULANG MAYKAPANGYARIHAN.**

THIS MUST BE POSTED ON CONSPICUOUS PLACE AND BE PRESENTED UPON DEMAND BY PROPER AUTHORITIES.

**RBSanchez PME Consultants & Associates, Inc.**



# BIR AND SSS REGISTRATION

REPUBLIC OF THE PHILIPPINES  
KAGAWARAN NG PANANALAPI  
KAWANIHAN NG RENTAS INTERNAS  
REVENUE REGION NO. 008 - MAKATI  
REVENUE DISTRICT OFFICE NO. 048 - WEST MAKATI

Page 1 of 1

BIR Form No. 2303  
Revised November 2014

OCN: 9RC0001418871E  
Date: February 08, 2018

## CERTIFICATE OF REGISTRATION

TIN / BRANCH CODE 007-570-182-00000	NAME OF TAXPAYER RBSANCHEZ PME CONSULTANTS & ASSOCIATES INC.	TIN ISSUE DATE February 12, 2010
REGISTERING OFFICE X Head Office	Branch	
REGISTERED ADDRESS U-2807 28/F CITYLAND PASONG TAMO TOWER, 2210 CHINO ROCES AVE., PIO DEL PILAR, CITY OF MAKATI NCR, FOURTH DISTRICT PHILIPPINES 1230		

TAX TYPES	FORM TYPES	FILING START DATE	TAX TYPES	FORM TYPES	FILING START DATE
DOCUMENT STAMP TAXES - REGULAR	2000	February 12, 2010	WITHHOLDING TAX - COMPENSATION	1601C	March 31, 2010
REGISTRATION FEE	0605	December 31, 2010	VALUE ADDED TAX	2550M	March 31, 2010
MISCELLANEOUS TAX	0605	October 11, 2011	VALUE ADDED TAX	2550Q	March 31, 2010
CORPORATE INCOME TAX	1702	December 31, 2010	WITHHOLDING TAX - EXPANDED/OTHERS	1601E	February 08, 2018
CORPORATE INCOME TAX	1702Q	March 31, 2010	WITHHOLDING TAX - EXPANDED/OTHERS	1604E	February 08, 2018
WITHHOLDING TAX - COMPENSATION	1604CF	December 31, 2010			

TAXPAYER TYPE/S DOMESTIC CORPORATION

TRADE NAME 1	CATEGORY	REGISTRATION DATE
RBSANCHEZ PME CONSULTANTS & ASSOCIATES INC.		February 12, 2010
Line of Business (PSIC)	70200 MANAGEMENT CONSULTANCY ACTIVITIES	Primary

REMITTERS:

- PAYMENT OF ANNUAL REGISTRATION FEE ON OR BEFORE JANUARY 31, USING BIR FORM NO. 0605
- FILING OF REQUIRED TAX RETURN/S TO CONFORM WITH THE ABOVE TAX TYPE/S, WHETHER WITH OR WITHOUT BUSINESS OPERATION, TO AVOID PENALTIES
- THE FOLLOWING SHALL LIKEWISE BE ACCOMPLISHED:
  - APPLICATION FOR REGISTRATION OF MANUAL BOOKS OF ACCOUNTS AND/OR COMPUTERIZED ACCOUNTING SYSTEM OR COMPONENTS THEREOF (BIR FORM NO. 1900)
  - APPLICATION FOR AUTHORITY TO PRINT MANUAL RECEIPTS AND INVOICES (BIR FORM NO. 1906)
- IMMEDIATELY INFORM THIS DISTRICT OFFICE IN CASE OF TRANSFER/CESSATION OF BUSINESS AND OTHER CONCERNS BY FILING BIR FORM NO. 1905 TO STOP GENERATION OF OPEN CASES

I HEREBY CERTIFY THAT THE ABOVE NAMED PERSON IS REGISTERED AS INDICATED ABOVE, UNDER THE PROVISIONS OF THE NATIONAL INTERNAL REVENUE CODE, AS AMENDED.

REBE D. DETABLAN  
REVENUE DISTRICT OFFICER (Signature over Seal)  
LUCY D. ABRASIA  
Revenue District Officer

THIS CERTIFICATION MUST BE EXHIBITED CONSPICUOUSLY IN THE PLACE OF BUSINESS



Republic of the Philippines  
SOCIAL SECURITY SYSTEM

2019  
OCTOBER

## CERTIFICATE OF REGISTRATION

*This is to certify that*

### RBSANCHEZ PME CONSULTANTS

2210 U2807 28/F CITYLAND PASONG TAMO TOWER CHINO ROCES AVENUE, PIO DEL PILAR, CITY OF MAKATI, NCR 1230

has been duly registered with the Social Security System (SSS) as employer on **01 July 2010** with Employer Number **03-9248034-1-000**.

Pursuant to the Social Security Law, the employer has the responsibility to report all its employees to the SSS for coverage, deduct from their monthly salaries their respective shares of the SS contributions and, with the corresponding employer's share, remit the same to the SSS. It also has the responsibility to deduct from the salaries of its employees, their monthly loan amortization, if any, and remit them to the SSS.

This certification is issued this 17<sup>th</sup> day of October, 2019.

*Aurora C. Ignacio*  
AURORA C. IGNACIO  
President and CEO

20191017-124212-6

## RBSanchez PME Consultants & Associates, Inc.



# PROFESSIONAL PRC PTR TAX & PME REGISTRATION

OFFICIAL RECEIPT		
Republic of the Philippines <b>City of Makati</b> <b>OFFICE OF THE TREASURER</b>		
MISCELLANEOUS TAXES AND FEES DIVISION 101		
Accountable Form No. 51 Revised January, 1992	<b>ORIGINAL</b>	
DATE 01/03/2024	No. <b>10076158MK</b> <b>MKT 10076158</b>	
PAYOR <b>TRAN #: 0038214</b> <b>SANCHEZ, ROSENDO B.</b>		
NATURE OF COLLECTION	FUND AND ACCOUNT CODE	AMOUNT
PROFESSIONAL TAX	Php	300.00
Sub-Total	Php	300.00
PROFESSIONAL MECHANICAL ENGINEER, 2024,		PHP 300.00
AMOUNT IN WORDS THREE HUNDRED PESOS		12/31/2024
Received: <input checked="" type="checkbox"/> Cash <input type="checkbox"/> Treasury Warrant <input type="checkbox"/> Check <input type="checkbox"/> Money Order	Received the Amount Stated Above. <b>MARIA THERESA A. TAN</b>	
Treasury Warrant, Check, Money Order Number	<b>JESUSA E. CUNETA</b> City Treasurer City Treasurer Collecting Officer	
Date of Treasury Warrant, Check, Money Order <b>Cash PHP 300.00</b>		

Note: Write the number and date of this receipt on the back of treasury warrant, check or money order received

Republic of the Philippines <b>PROFESSIONAL REGULATION COMMISSION</b> PROFESSIONAL IDENTIFICATION CARD	
	LAST NAME ▶ <b>SANCHEZ</b> FIRST NAME ▶ <b>ROSENDO</b> MIDDLE NAME ▶ <b>BARRIOS</b> REGISTRATION NO. ▶ <b>0003999</b> REGISTRATION DATE ▶ <b>05/05/2003</b> VALID UNTIL ▶ <b>12/22/2025</b>
<b>PROFESSIONAL MECHANICAL ENGINEER</b>	
	



# SAMPLE TESTING AND MEASUREMENT PRECISION INSTRUMENTS





# USE OF SUPERCOMPUTERS FOR “REALISTIC” PROBLEM-SOLVING SIMULATION OF DESIGN CONCEPTS AND OPERATIONAL PROBLEMS

THREE (3) SUPERCOMPUTER SERVERS units of Hewlett Packard Proliant Brand and HP DL-380 Servers each of 32-cores 3.0 MHz Intel Xeon Double Processors





# SAMPLE CALIBRATION CERTIFICATES



## CALIBRATION CERTIFICATE

<b>CERTIFICATE NUMBER</b>	: CTM 3073-18	<b>JOB NUMBER</b>	: CTJ 18-6556
<b>DATE RECEIVED</b>	: 28-Sep-18	<b>ISSUE DATE</b>	: 16-Oct-18
<b>Instrument</b>	: ULTRASONIC FLOW METER	<b>Ambient Temperature</b>	: (23 ± 5) °C
<b>Manufacturer</b>	: ---	<b>Relative Humidity</b>	: (55 ± 10) % r.h.
<b>Model No.</b>	: TUF-2000M	<b>Date Calibrated</b>	: 16-Oct-18
<b>Part No.</b>	: ---	<b>Recommended Due Date</b>	: 16-Oct-19
<b>Serial No.</b>	: 18207057		
<b>Customer</b>	: RBSANCHEZ PME CONSULTANTS & ASSOCIATES, INC Unit 3003, 30th Floor, Makati Executive Tower 2 oor Osmena & Buendia Ave, Makati City, Postal Code: 1250 Metro Manila, Philippines	<b>Range</b>	: ---
		<b>(Tag No.)</b>	: ---
		<b>Page</b>	: 1 of 2
		<b>Status</b>	: As Found

The described instrument has been calibrated at Caltek Laboratory under the ambient conditions stated above.

This certificate provides traceability of measurement to the International System of Units (SI) and/or to units of measurement realised at the National Metrology Centre (NMC), Singapore or other recognized national metrology institutes.

**METHOD** : The calibration method was carried out according to in-house Technical Calibration Procedure CTM - M22-2007, as a guide.

REFERENCE INSTRUMENT(S)	SERIAL NO
1. Liquid Flow Calibrator	23148

### RESULTS OF CALIBRATION

- The results of calibration are given on the attached calibration data sheet(s).
- The expanded uncertainty of measurement associated with the calibration is 2.0 % of reading estimated at a confidence level of approximately 95 % with a coverage factor of k=2.00.
- The user should determine the suitability of the instrument for its intended use.

Calibrated by:  
PREMKUMAR, S  
EMP ID : 1022

Approved by:  
AYYAPPAN, M  
EMP ID : 1011

This certificate may not be reproduced other than in full, except with the prior written approval of the issuing Laboratory.



## TEST REPORT

<b>REPORT NUMBER</b>	: CTM 3014-18	<b>JOB NUMBER</b>	: CTJ 18-6556
<b>DATE RECEIVED</b>	: 28-Sep-18	<b>ISSUE DATE</b>	: 16-Oct-18
<b>Item</b>	: FORMALDEHYDE DETECTOR	<b>Ambient Temperature</b>	: (23 ± 5) °C
<b>Manufacturer</b>	: WAYSEAR	<b>Relative Humidity</b>	: (55 ± 10) % r.h.
<b>Model No.</b>	: GT55A	<b>Date of Test</b>	: 16-Oct-18
<b>Part No.</b>	: ---	<b>Recommended Due Date</b>	: 16-Oct-19
<b>Serial No.</b>	: ---		
<b>Customer</b>	: RBSANCHEZ PME CONSULTANTS & ASSOCIATES, INC Unit 3003, 30th Floor, Makati Executive Tower 2 oor Osmena & Buendia Ave, Makati City, Postal Code: 1250 Metro Manila, Philippines	<b>Range</b>	: ---
		<b>(Tag No.)</b>	: ---
		<b>Page</b>	: 1 of 1
		<b>Status</b>	: As Found

The described instrument has been tested at Caltek Laboratory under the ambient conditions stated above.

**METHOD** : The test method was carried in accordance with manufacturer's specification procedure as a guide.

### RESULTS OF TEST

FUNCTION TEST	CHECK	REMARKS/RESULTS
VISUAL INSPECTION	DENT/PHYSICAL DAMAGE	ACCEPTABLE
RESPONSE TIME	DIGITS SENSITIVITY	ACCEPTABLE
SAMPLING PUMP	VACUUM ACTION	ACCEPTABLE
HCHO DETECTION(mg/m <sup>3</sup> )	DETECTED	ACCEPTABLE
TVOC DETECTION(mg/m <sup>3</sup> )	DETECTED	ACCEPTABLE
PM 2.5 DETECTION (<2.5 µg/m <sup>3</sup> )	DETECTED	ACCEPTABLE

Remark: The user should determine the suitability of the item for its intended use.

Tested by:  
AYYAPPAN, M  
EMP ID : 1011

Approved by:  
V.SIVA  
EMP ID : N/A

This certificate may not be reproduced other than in full, except with the prior written approval of the issuing Laboratory.



# RBS Office Location

Unit 3603, 36F Makati Executive Tower II, Buendia Ave. cor.  
Dela Rosa St. Brgy. Pio Del Pilar, Makati City  
Philippines 1230



RBS has eight (8) private parking spaces at Cityland Condo. Alternatively, public may park just across the RBS offices is SM Hypermarket and also at nearby Cash and Carry Mall, Buendia Makati.





# CONTACT US!

## RBSanchez PME Consultants & Associates, Inc.



Unit 3603, 36F Makati Executive Tower II, Buendia Ave. cor. Dela Rosa St.  
Brgy. Pio Del Pilar, Makati City Philippines 1230



(+632) 8776-5879, 8638-2604,  
8809-8106;



(+63) 927-300-6000 / 947-507-000



[info@rbs-engineers.com](mailto:info@rbs-engineers.com)  
[rosensanchez@yahoo.com](mailto:rosensanchez@yahoo.com)



[www.rbs-engineers.com](http://www.rbs-engineers.com)



# Thank you!

## RBSanchez PME Consultants & Associates, Inc.



Unit 3603, 36F Makati Executive Tower II, Buendia Ave. cor. Dela Rosa St.  
Brgy. Pio Del Pilar, Makati City Philippines 1230



(02) 8776 – 5879



(+63) 927-300-6000 / 947-507-000



[info@rbs-engineers.com](mailto:info@rbs-engineers.com)  
[rosensanchez@yahoo.com](mailto:rosensanchez@yahoo.com)



[www.rbs-engineers.com](http://www.rbs-engineers.com)